

L. Roberto Lomas P.E.

400 S Palm Ave
Indialantic, FL 32903
434-688-0609

Engineering Evaluation Report

Report No.: 513453D

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Fort Myers, FL 33912

Product Line: Series FWI 1000 Aluminum Horizontal Sliding Window - LMI

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02678, revision C, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: FTL 02-311-25 signed and sealed by Joseph Chan, P.E.
Fenestration Testing Laboratory, Inc., Hialeah, FL
TAS 201/TAS 203 Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Pressure loading ± 80.0 psf design pressure
TAS 202 Uniform Static Air Pressure, ± 80.0 psf design pressure, 12.0psf water penetration.
3. Anchor calculations, report number 513453-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 80.0 psf
- Unit size: 72" x 60"
- Units must be glazed per ASTM E1300 according to glass details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T6.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02678, revision C.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

