

L. Roberto Lomas P.E.

400 S Palm Ave
Indialantic, FL 32903
434-688-0609

Engineering Evaluation Report

Report No.: 513455D

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Fort Myers, FL 33912

Product Line: Series FWI 1000 Aluminum Horizontal Sliding Window - LMI

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02680, revision C, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL-210-3752-1 signed and sealed by Gerard J Ferrara, P.E.
National Certified Testing Laboratories, Orlando, FL
TAS 201 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 Uniform Static Air Pressure, +100.0/-120.0psf design pressure, 15.0psf water penetration.
TAS 203 Cyclic Pressure loading +100.0/-120.0psf design pressure
3. Anchor calculations, report number 513455-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: +100.0/-120.0psf
- Unit size: 120" x 63"
- Units must be glazed per ASTM E1300 according with glass details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T5.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02680, revision C.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

