L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 511737E

Manufacturer: Nan Ya Plastics Corporation

8989 North Loop East Houston, TX 77029

Product Line: Series 9'0 x 8'0 Fiberglass Out-swing Glazed Double Door w/ and w/o Sidelites

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

Approval document: drawing number 08-01166 revision C, prepared, signed and sealed by Luis Roberto Lomas P.E.

1. Report No.: CTLA 1420W-2 signed and sealed by Ramesh Patel P.E.

Certified Testing Laboratories, Orlando, FL

AAMA/WDMA/ČSA 101/I.S.2/A440
Design pressure: ±50.0psf
Water penetration resistance 7.5psf

2. Report No.: CTLA 1508W-1 signed and sealed by Ramesh Patel P.E.

Certified Testing Laboratories, Orlando, FL

ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
Cyclic Load Test, ±50.0psf design pressure

3. Anchor calculations, report number 511736-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Maximum design pressure: ±50.0psf
Maximum unit size: ±50.0psf
109" x 95 ½"

- Units must be glazed per ASTM E1300 according to glazing details in approval drawing.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.

Installation:

Units must be installed in accordance with approval document, 08-01166 revision C.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/05/2020