## L. Roberto Lomas P.E.

# **Engineering Evaluation Report**

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

**Report No.: 514399A** 

Manufacturer: Nan Ya Plastics Corp. USA

8989 North Loop East Houston, TX 77029

Product Line: In-Swing Entrance Door with Sidelites Fiberglass

#### Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

## Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03400, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Report No.: FTL 6719 signed and sealed by Marlin D. Brinson P.E.

Fenestration Testing Laboratory, Inc. Medley, FL

AAMA/WDMA/CSA101/I.S.2/A440

Design pressure: ±60.0psf
Water penetration resistance £6.0psf

3. Anchor calculations, report number 514399-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

## Limitations and Conditions of use:

Maximum design pressure: ±40.0psf

Maximum unit size: 145 3/4" x 82 ½"

- Units must be glazed per ASTM E1300, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be CO-Extruded PVC Foam.

### Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03400.

## Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

