L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 514400A

Manufacturer: Nan Ya Plastics Corp. USA

8989 North Loop East Houston, TX 77029

Product Line: Out-Swing Entrance Door with and without Sidelites Non-Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03401, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Report No.: FTL 6716 signed and sealed by Marlin D. Brinson P.E.

Fenestration Testing Laboratory, Inc., Medley, FL

AAMA/WDMA/CSA101/I.S.2/A440

Design pressure: ±70.0psf Water penetration resistance 10.5psf

3. Anchor calculations, report number 514400-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Maximum design pressure: ±65.0psf

• Unit size: 143 1/8" x 82 1/2"

- Units must be glazed per ASTM E1300, with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be CO-Extruded PVC Foam.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03401.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/05/2020