



R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

Product Evaluation Report

Report No.: FL-15146.4

Date: March 16, 2026

Product Category	Sub Category	Manufacturer	Product Name
Sky Lights	Skylight	Gammans Skylight Systems, Inc. 10 Beavers St. Newnan, GA 30263 Phone - 770.254.1992	Series 500 & 700 Aluminum Fixed Skylight System "Large Missile Impact"

Scope: Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Gammans Skylight Systems, Inc., based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. When used in areas requiring wind borne debris protection, this product complies with FBC Section 1609.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E 1996 and FBC Section 1609.1.2.2.
3. The system detailed herein is generic and does not provide information for a specific site. A licensed engineer or registered architect shall prepare site specific documents (including framing support and connections) to be used in conjunction with this document.
4. Permit holder shall verify the adequacy of the existing structure to withstand new superimposed loads.
5. See drawing FL-15146.4 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|---|---|--|
| 1. Test Report No.
ATLNC 0630.1-04
ATLNC 0630.1-04 | Test Standard
TAS 202-94
ASTM E 1886/1996-02 | Testing Laboratory
American Test Lab., Inc.
American Test Lab., Inc. | Signed by
David Johnson, P.E.
David Johnson, P.E. |
| 2. Miami-Dade NOA
23-0717.30 | Materials Testing
SentryGlas Interlayer (Kuraray America) | | |
| 3. Drawing No.
No. FL-15146.4 | Prepared by
RW Building Consultants, Inc. (#9813) | | Signed & Sealed by
Lyndon F. Schmidt, P.E. |
| 4. Calculations
ASTM E 1300 Glass Load | Prepared by
RW Building Consultants, Inc. (#9813) | | |
| 5. Quality Assurance
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Gammans Skylight Systems, Inc. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
This item has been digitally signed and sealed by L. F. Schmidt on 3-18-26.
Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA