

Product Evaluation Report**Report No.:** FL-15362.1**Date:** August 11, 2020

| Product Category | Sub Category | Manufacturer | Product Name |
|------------------|-----------------------------------|--|--|
| Exterior Doors | Swinging Exterior Door Assemblies | Dunbarton Corporation 868 Murray Road Dothan, AL 36303 Phone 334.794.0661 | Achiever Steel Frame System Utilizing a Steel Door Panel Inswing "Non-Impact" |

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Dunbarton Corporation based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.


RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

1. This product has been evaluated and is in compliance with the 7th Edition (2020) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
4. Site conditions that deviate from the details of drawing FL-15362.1 require further engineering analysis by a licensed engineer or registered architect.
5. See drawing FL-15362.1 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|--|--|---|--|
| 1. Test Report No. TEL 01090355 TEL 01090171 CTLA 1112W-1 | Test Standard ASTM E330 (02), E331 (00) AAMA/WDMA/CSA101/1.S.2/A440 (05) ASTM E330 (02), E331 (00) | Testing Laboratory Certified Testing Lab., Inc. Testing Evaluation Lab., Inc. Testing Evaluation Lab., Inc. | Signed by Ramesh Patel, P.E. Vivian K. Wright Vivian K. Wright |
| 2. Drawing No. No. FL-15362.1 | Prepared by RW Building Consultants, Inc. (#9813) | Signed & Sealed by Lyndon F. Schmidt, P.E. | |
| 3. Calculations Anchoring | Prepared by RW Building Consultants, Inc. (#9813) | Signed & Sealed by Lyndon F. Schmidt, P.E. | |
| 4. Quality Assurance Certificate of Participation issued by National Accreditation and Management Institute, certifying that Dunbarton Corporation is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |



Lyndon F. Schmidt, P.E.
FL PE No. 43409
8/11/2020