



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Product Evaluation Report

of

**JELD-WEN, inc.
Custom Collection Aluminum Clad Wood Mullion Assemblies
(Non-HVHZ) (Non-Impact)**

for

Florida Product Approval

Report No. 8300

Current Florida Building Code

Method:	1 – D (Engineering Evaluation)
Category:	Windows
Sub – Category:	Mullions
Product:	Custom Collection Aluminum Clad Wood Mullion Assemblies
Material:	Pressure Treated Pine (Auralast®) w/ Aluminum 6063-T5 cladding

Prepared for:

**JELD-WEN, inc.
3737 Lakeport Blvd.
Klamath Falls, OR. 97601**

Prepared by:

Hermes F. Norero, P.E.
Florida Professional Engineer # 73778
Date: 02/02/2023

Contents:


Evaluation Report Pages 1 – 4

 954.399.8478

 954.744.4738

 BUILDINGDROPS.COM

 CONTACT@BUILDINGDROPS.COM



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Manufacturer: JELD-WEN, inc.

Product Category: Windows

Product Sub-Category: Mullions

Compliance Method: State Product Approval Method (1)(d)

Product Name: Custom Collection Aluminum Clad Wood Mullion Assemblies
(Non-HVHZ) (Non-Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **JELD-WEN, inc.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **JW068**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the “High Velocity Hurricane Zone” (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does not** require an impact resistant covering when used in Wind Borne Debris Region Zone 3 or less. Individual window units must be impact rated where applicable.
4. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does** require an impact resistant covering when used in Wind Borne Debris Region Zone 4.
5. Site conditions that deviate from the details of drawing **JW068** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **JW068** for size and design pressure limitations.

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Quality Assurance: The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Window and Door Manufacturers Association**. (FBC Organization # QUA2515)

Performance Standards: The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-08
- AAMA 450-10

Referenced Data:

1. Product Testing performed by **Quality Testing, Inc.** (FBC Organization # TST7638)

JELD-WEN Custom Collection Casement Family		
No.	Report	Report Date
1	SJW2007-318	04/01/08
2	SJW2007-320	04/01/08
3	SJW2007-325	04/01/08
4	SJW2008-065	03/12/08
5	SJW2008-066	10/06/08
6	SJW2008-126	10/17/08

JELD-WEN Custom Collection Double Hung Family		
No.	Report	Report Date
1	SJW2007-317	04/01/08
2	SJW2007-319	04/01/08
3	SJW2007-322	04/01/08
4	SJW2007-323	12/19/07
5	SJW2007-324	04/01/08
6	SJW2008-131	10/17/08

2. Quality Assurance
Window and Door Manufacturers Association
(FBC Organization #: QUA2515)

Installation Method: Please refer to Installation instructions, (**JW068**), for anchor methods, selection, spacing, edge distances, embedment's and further details of installation.

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

Design Pressure: Please refer to Installation instructions, (**JW068**), for sizes, configurations and design pressures.

Equivalence of Test Standards:

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. JELD-WEN, inc. has tested their products to the following test standard edition(s):

- 1) AAMA/WDMA/CSA 101/I.S.2/A440-05
- 2) AAMA 450-06

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) AAMA/WDMA/CSA 101/I.S.2/A440-08
- 2) AAMA 450-10

After review of the above mentioned referenced standards and editions, it has been found that no significant technical changes have been made to the test standards that would affect the results. All referenced standards have been found to be equivalent.