

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@rlomaspe.com

Engineering Evaluation Report

Report No.: 512462D

Manufacturer: Eastern Architectural Systems
16341 Domestic Ave.
Ft Myers, FL 33912

Product Line: Series 143 Vinyl Awning Impact Window – 53 1/8” x 39”

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01778 Revision C prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: ESP101311P-1 signed by Ramesh C. Patel P.E.
Element Materials Technology, Wausau, WI
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±70.0psf Water penetration resistance: 12.0psf
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
Cyclic Load Test, +65.0/-70.0psf design pressure
3. Report No.: ESP101311P-2 signed by Ramesh C. Patel P.E.
Element Materials Technology, Wausau, WI
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±70.0psf Water penetration resistance: 12.0psf
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
Cyclic Load Test, +65.0/-70.0psf design pressure
4. Test report No.: ESP101311P signed by Ramesh C. Patel P.E.
Element Materials Technology, Wausau, WI
TAS 201 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 Uniform Static Air Pressure, +65.0/-70.0psf design pressure, 12.0psf water penetration.
TAS 203 Cyclic Pressure loading +65.0/70.0psf design pressure
5. Test report No.: ESP101311P-3 signed by Ramesh C. Patel P.E.
Element Materials Technology, Wausau, WI
TAS 201 Large Missile Impact Test, Level D, Wind Zone 4
TAS 202 Uniform Static Air Pressure, +65.0/-70.0psf design pressure, 12.0psf water penetration.
TAS 203 Cyclic Pressure loading +65.0/-70.0psf design pressure
6. Anchor calculations, report number 512462-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: +65.0/-70.0psf
- Maximum unit size: 53 1/8” x 39”
- Units must be glazed per ASTM E1300 according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

Installation:

Units must be installed in accordance with manufacturer’s installation instructions and approval document, 08-01778 Revision B.

Certification of Independence:

Please note that I don’t have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don’t have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

