### L. Roberto Lomas P.E.

# **Engineering Evaluation Report**

1432 Woodford Rd Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

**Report No.: 514422A** 

**Manufacturer:** Solar Innovations, Inc.

31 Roberts Rd

Pine Grove, PA 17963

**Product Line:** Series SI8100 Sliding Glass Door 5 x 8 Panel, Non-Impact

#### Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

## Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03418 revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: NCTL 110-15153-1 signed and sealed by Robert H Zeiders P.E.
  - National Certified Testing Laboratories, York, PA
  - TAS 202 Uniform Static Air Pressure, ±65.0psf design pressure, 12.0psf water penetration.
- 3. Anchor calculations, report number 514422-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 4. Comparative analysis, report number 514422-2, prepared, signed and sealed by Luis Roberto Lomas P.E.

#### Limitations and Conditions of use:

- Maximum design pressure: Refer to approval drawing.
- Approved configurations: Units with 4 panels maximum in unlimited configurations are approved as long as

individual panel area does not exceed 41.59 ft<sup>2</sup> and frame area does not exceed


- 254.48 ft<sup>2</sup> and uses vertical conditions as shown in approval drawing.
- Units must be glazed per ASTM E1300 with safety glazing.
- This product is rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Extruded Aluminum 6063-T6.

### Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-03418 Revision A.

### Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 11/17/2020