

L. Roberto Lomas P.E.

400 S Palm Ave
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 512502C

Manufacturer: US Aluminum
950 Solon Rd.
Waxahachie, TX 75165

Product Line: 451 Center Glaze Aluminum Store Front.

Compliance:

The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01816 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.:ATI-79241.01-801-47 signed by Andy Cost
Architectural Testing Inc., South Lake, TX
ASTM E330
Design pressure ± 30.0 psf
Water penetration: 8.0psf
3. Test report No.: ATLNC 0724.01-06 signed and sealed by David Johnson P.E.
American Test Lab, Inc., Brevard, NC
AAMA 501 and TAS 202
Uniform Static Air Pressure, ± 65.0 psf design pressure, 15.0 water penetration
4. Anchor calculations and comparative analysis, report number 512502-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 30.0 psf (Refer to installation instructions for smaller sizes rating)
- Panel size: 62" x 96"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be extruded Aluminum 6063-T5.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-01816 Revision B.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

