

Product Evaluation Report **Report No.: FL-16216.2**
Date: October 16, 2023

| Product Category | Sub Category | Manufacturer | Product Name |
|------------------|----------------------------------|--|---|
| Exterior Doors | Sliding Exterior Door Assemblies | Wincore Window Company, LLC. 250 Staunton Turnpike Parkersburg, WV 26104 | 8800 Series Vinyl Sliding Patio Door "Impact" |

Scope: This is a Product Evaluation report issued by R W Building Consultants, Inc. and Lyndon F. Schmidt, P.E. (System ID # 1998) for Wincore Window Company, LLC. based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Department of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

Limitations:

- This product has been evaluated and is in compliance with the 8th Edition (2023) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in areas requiring wind borne debris protection this product complies with FBC Sections 1609.1.2 & R301.2.1.2 and does not require an impact resistant covering. This product meets missile level "D" and includes Wind Zone 4 as defined in ASTM E1996 and FBC Sections 1609.1.2.2 & R301.2.1.2.1.
- For 2x stud framing construction, anchoring of these units shall be the same as that shown for 2x buck masonry construction.
- Site conditions that deviate from the details of drawing FL-16216.2 require further engineering analysis by a licensed engineer or registered architect.
- See drawing FL-16216.2 for size and design pressure limitations.

Supporting Documents:

- | | | | |
|---|--|---|--|
| 1. Test Report No. NCTL 110-15906-1 NCTL 110-16274-1 | Test Standard AAMA/WDMA/101/I.S.2/A440-08 ASTM E 1886-05 / E 1996-09 | Testing Laboratory NCTL NCTL | Signed by Robert H. Zeiders, P.E. Robert H. Zeiders, P.E. |
| 2. Miami-Dade NOA 23-0713.18 | Materials Testing Saflex® PVB Interlayer (Eastman Chemical Company) | | |
| 3. Drawing No. No. FL-16216.2 | Prepared by RW Building Consultants, Inc. (#9813) | | Signed & Sealed by Lyndon F. Schmidt, P.E. |
| 4. Calculations Anchoring ASTM E1300 Glass Load | Prepared by RW Building Consultants, Inc. (#9813) RW Building Consultants, Inc. (#9813) | | Signed & Sealed by Lyndon F. Schmidt, P.E. |
| 5. Quality Assurance Certificate of Participation issued by National Accreditation and Management Institute, certifying that Wincore Window Company, LLC. is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53. | | | |

LYNDON F. SCHMIDT, State of Florida, Professional Engineer, License No. 43409
 This item has been digitally signed and sealed by L. F. Schmidt on 10-18-23.
 Printed copies of this document are not considered signed and sealed and the signature must be verified on any electronic copies.
THIS PRODUCT APPROVAL IS VALID ONLY FOR THE STATE OF FLORIDA