



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 East Dania Beach Blvd.
Suite 338
Dania Beach, FL 33004
954.399.8478 PH
954.744.4738 FX
contact@buildingdrops.com

Product Evaluation Report

of

**The Folding Sliding Door Company FSD Works
HD82-70 MM Folding Infolding Door System**

for

Florida Product Approval

FL# FL16291

Report No. 6334

Current Florida Building Code

| | |
|----------------------------|---|
| Method: | 1 – D (Engineering Evaluation) |
| Category: | Exterior Doors |
| Sub – Category: | Swinging Exterior Door Assemblies |
| Product: | HD82-70 MM Folding Infolding Door System |
| Material: | Aluminum 6063-T5 |
| Product Dimensions: | 223.75" x 96.0625" (Tested Size) |

Prepared for:

**The Folding Sliding Door Company FSD Works
Hopbine Avenue, West Bowling
Bradford, West Yorkshire, BD5 8ER, UK**

Prepared by:


Hermes F. Norero, P.E.

Florida Professional Engineer # 73778

Date: 07/03/2019

Contents:

Evaluation Report Pages 1 – 4



Hermes F. Norero, P.E.
Florida No. 73778



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL16291
Date: 07/03/2019
Report No: 6334

Manufacturer: The Folding Sliding Door Company FSD Works

Product Category: Exterior Doors

Product Sub-Category: Swinging Exterior Door Assemblies

Compliance Method: State Product Approval Method (1)(d)

Product Name: **HD82-70 MM Folding Infolding Door System**
223.75" x 96.0625" (Tested Size)
(Non-Impact)

Scope: This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **The Folding Sliding Door Company FSD Works** based on Method 1d of the State of Florida Product Approval, Florida Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code.

See Installation Instructions **FSD003**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

1. This product has been evaluated and is in compliance with the Florida Building Code, excluding the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Florida Building Code and does require an impact resistant covering.
4. Site conditions that deviate from the details of drawing **FSD003**, require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **FSD003**, for size and design pressure limitations.



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL16291
Date: 07/03/2019
Report No: 6334

-
- Quality Assurance:** The manufacturer has demonstrated compliance of door products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **National Accreditation Management Institute**. (FBC Organization # QUA1789)
- Performance Standards:** The product described herein has been tested per:
- TAS 202-94
 - ASTM E 1300-04
- Referenced Data:**
1. Product Testing performed by **National Certified Testing Laboratory, Inc.** (FBC Organization # TST9341)
Report #: NCTL-210-3846-1, Report Date: 02/01/2013
Signed and Sealed by Gerard Ferrara P.E. #11985
 2. Quality Assurance
National Accreditation Management Institute
(FBC Organization #: QUA1789)



BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

FL#: FL16291

Date: 07/03/2019

Report No: 6334

Installation: 1. Approved anchor types and substrates are as follows:

Through Frame Installation:

- A. For two by (2X) wood buck substrate, use **#12 Wood Screw** type installation anchors of sufficient length to achieve a minimum embedment of 3" into the wood substrate.
- B. For concrete or masonry substrate where one by (1X), non-structural, wood bucking is employed **OR** where wood bucking is not employed, use **3/16" diameter ITW Tapcon or Elco Ultracons** type concrete screw anchors of sufficient length to achieve minimum embedment of 1 3/4" into concrete or masonry.
- C. Alternatively, for concrete/masonry substrates, anchors may be **7.5 mm (5/16" Nominal) Timco T30 Torx Concrete Screws**, of sufficient length to achieve 1 3/4" minimum embedment with a minimum 2 1/2" edge distance.
- D. For steel substrate (Min. 18 ga. steel, min. $f_y = 33$ ksi), use **#12 TEK Screw** type steel stud anchors of sufficient length to achieve minimum 3 threads penetration beyond steel structure.

Design Pressure:

Refer to Installation Instructions (**FSD003, Sheet 8**) for applicable design pressures.

Installation Method:

Refer to Installation Instructions (**FSD003**) for anchor spacing, methods, locations, and more details of the installation requirements.