

Product Description: 07-09/10 Stormbreaker Plus 300VL Horizontal Slider EndVent Window Series, XOX Equal Lite Configuration

Manufacturer: Simonton Windows, 1 Cochrane Ave., Pennsboro, WV

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8th Edition (2023) Florida Building Code including the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Installation drawing DA0015r2, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports SIMO-028-03-02 from PRI, Tampa, FL and SV30832-20170201, from UL LLC, Northbrook, IL, TAS testing signed and sealed by Alexis Spyrou, P.E., with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-11/17, TAS201/202/203-94
- 4) Supplemental Calculations to support DA0015r2, signed and sealed by Lucas A. Turner, P.E.
- 5) Test Report ETC-97-264-4091.0, from ETC Laboratories, Rochester, NY, signed and sealed by J. L. Doldan, P.E., report used for PVC extrusion Dade master files, with testing performed: ASTM D1929 Ignition Temperature, ASTM D2843 Smoke Density, ASTM D635 Rate of Burning, ASTM G26 UV Exposure for 4500 hours, ASTM D638. Testing is equivalent to flame, smoke, UV, and tensile standards as required per FBC 2023 and Miami-Dade Plastics checklist #0445.

Installation: Units must be installed according to installation drawing DA0015r2.

Limitations of Use: This product:

- May be used in the configurations and product sizes as indicated in DA0015r2
- Is large and small missile impact resistant and does not require the use of impact protective devices in windborne debris regions
- May be used in the High Velocity Hurricane Zone
- Requires white SimEx, Inc. PVC extrusions in accordance with Technical Documentation 5) above, with current listing as an AAMA Certified Profile Licensee under AAMA 303
- Requires Eastman Solutia/Saflex HP PVB Interlayer per current Miami-Dade NOA. I have evaluated this interlayer material and find that it complies with the requirements of the 8th Ed. (2023) Florida Building Code for use in this product.

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Simonton Windows or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



12/6/2023
Lucas A. Turner, P.E.
FL PE #58201