L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 512667H

Manufacturer: Provia, LLC.

2150 State Route 39 Sugarcreek, OH 44681

Product Line: Steel Inswing Glazed Door – Single and Double – Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-01957 Revision H, signed and sealed by Luis Roberto Lomas P.E.

2. Report No.: NCTL 110-15660-1, Revision 7, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E330

Design pressure: ±55.0psf

3. Report No.: NCTL 110-15660-2, Revision 7, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3

Cyclic Load Test, ±55.0psf design pressure

4. Test Report No.: TEL 03851468, signed by William B. Shelton, P.E.

Testing Evaluation Laboratories, Inc., Plant City, FL.

TAS 201 Large Missile Impact Test, Level D, Wind Zone 4

TAS 202 Uniform Static Air Pressure, ±60.0psf design pressure, 9.0psf water penetration.

TAS 203 Cyclic Pressure loading ±60.0psf design pressure

5. Test Report No.: 3172703MID-011, signed by Kent Kelsey

Intertek Testing Services NA Inc., Middleton, WI

NFPA 252 & UL 10C.

Steel skin door with polyurethane foam core complies with NFPA 252 and UL 10C Positive Pressure Fire Test of Door Assemblies for a 90 minutes rating with hose stream.

6. Report No.: L0763.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3

Cyclic Load Test, ±50.13psf design pressure

7. Report No.: M2210.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3

Cyclic Load Test, ±50.13psf design pressure

8. Report No.: M4360.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3

Cyclic Load Test, ±50.13psf design pressure

9. Report No.: M4359.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA


ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3

Cyclic Load Test, ±50.13psf design pressure

 Anchor calculations, report number 512667-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

 Comparative analysis, report number 511679-2, prepared, signed and sealed by Luis Roberto Lomas P.E.



Luis R. Lomas, P.E. FL No.: 62514 08/10/2021

L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 512667H

- 12. Evaluation and comparative analysis for alternate sills, report numbers 514581A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 13. Evaluation and comparative analysis for alternate panels, report number 514394A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:


- Design pressure: ± 55.0psf
- Unit size: 74 1/32" x 97 19/32" (Double); 37 9/16" x 97 19/32" (Single)
- Units must be glazed per ASTM E1300, according to glazing details in approval drawing.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions up to wind zone 3.
- Door frame material: Wood G.46 minimum, or composite or Framesaver, or Fusion Frame.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-01957, Revision F.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 08/10/2021