L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 512753I

Manufacturer: Provia, LLC.

2150 State Route 39 Sugarcreek, OH 44681

Product Line: Steel/Fiberglass Inswing Opaque Double Door W/ Sidelites and Transom -Impact

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-02040 Revision I, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Report No.: NCTL 110-15660-2, Revision 7, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3 Cyclic Load Test, ±55.0psf design pressure

3. Report No.: NCTL 110-15660-1, Revision 7, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E330

Design pressure: ±55.0psf

Report No.: NCTL 110-15650-4, Revision 1, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±55.0psf
Water penetration resistance 8.25psf

5. Report No.: NCTL 110-15650-2, Revision 1, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3 Cyclic Load Test, ±55.0psf design pressure

Report No.: NCTL 110-15651-2, Revision 1, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3 Cyclic Load Test, ±55.0psf design pressure

7. Report No.: NCTL 110-15651-4, Revision 1, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440

Design pressure: ±55.0psf Water penetration resistance: 8.25psf

8. Report No.: NCTL 110-15652-2, Revision 1, signed and sealed by Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3 Cyclic Load Test, ±55.0psf design pressure


9. Report No.: NCTL 110-15652-3, Revision 1, signed and sealed by

Robert H Zeiders P.E.

National Certified Testing Laboratories, York, PA

AAMA/WDMA/CSA 101/I.S.2/A440

Design pressure: ±55.0psf Water penetration resistance: 8.25psf



Luis R. Lomas, P.E. FL No.: 62514 08/24/2021

L. Roberto Lomas P.E.

Engineering Evaluation Report

Report No.: 5127531

1432 Woodford Rd.

Lewisville, NC 27023

434-688-0609

rllomas@lrlomaspe.com

10. Test Report No.: TEL 03851468, signed by William B. Shelton, P.E.

Testing Evaluation Laboratories, Inc., Plant City, FL.

TAS 201 Large Missile Impact Test, Level D, Wind Zone 4

TAS 202 Uniform Static Air Pressure, ±60.0psf design pressure, 9.0psf water penetration.

TAS 203 Cyclic Pressure loading ±60.0psf design pressure

11. Test Report No.: 3172703MID-011, signed by Kent Kelsey

Intertek Testing Services NA Inc., Middleton, WI

NFPA 252 & UL 10C.

Steel skin door with polyurethane foam core complies with NFPA 252 and UL 10C Positive Pressure Fire Test of Door Assemblies for a 90 minute rating with hose stream.

12. Test reports: TEL01680148, TEL01680149 and TEL01680150 signed and sealed by Lyndon F. Schmidt P.E.

Testing Evaluation Laboratories, Inc. Plant City, FL

Fiberglass testing

ASTM D635 Rate of burning classification: CC1
ASTM D1929 Self ignition temperature: 778°F
ASTM D2843 Smoke density rating: 60.4

13. Report No.: L0763.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3 Cyclic Load Test, ±50.13psf design pressure

14. Report No.: M2210.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3 Cyclic Load Test, ±50.13psf design pressure

15. Report No.: M4360.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3 Cyclic Load Test, ±50.13psf design pressure

16. Report No.: M4359.01-501-47 R0, signed by Stephen D. Shank

Intertek, Springdale, PA ASTM E1886/ E1996

Large Missile Impact, Level D, Wind Zone 3

Cyclic Load Test, ±50.13psf design pressure

- 17. Anchor calculations, report number 512753-1B, prepared, signed and sealed by Luis Roberto Lomas P.E
- 18. Mullion analysis, report number 512753-2 and -3, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 19. Comparative analysis, report number 511679-2, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 20. Evaluation and comparative analysis for alternate sills, report numbers 514581A, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 21. Evaluation and comparative analysis, report number 514394A, prepared, signed and sealed by Luis Roberto Lomas P.E.


Limitations and Conditions of use:

• Design pressure: ±55.0psf

Panel size: 35 3/4" x 94 15/16"

 Sidelites and transom must be glazed per ASTM E1300, according to glazing details in approval drawing.

- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions up to wind zone 3.
- Door frame material: Wood G.46 minimum, or composite or Framesaver, or Fusion Frame.



Luis R. Lomas, P.E. FL No.: 62514 08/24/2021

L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com


Report No.: 512753I

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02040, Revision I.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 08/24/2021