



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

## Product Evaluation Report

of

**Allegion-Schlage Lock Company, LLC  
Outswing Single/Double Flush with Panic Door Hardware  
(HVHZ)(Impact)**

for

**Florida Product Approval**

**FL# FL16740**

**Report No. 8779**

**Current Florida Building Code**

**Method:** 1 – D (Engineering Evaluation)

**Category:** Exterior Doors

**Sub – Category:** Swinging Exterior Door Assemblies

**Product:** Outswing Single/Double Flush with Panic Door Hardware

**Product Dimensions:** See Installation Instructions F1049DF/F1049SF

**Prepared for:**

**Allegion-Schlage Lock Company, LLC.**

**11819 N. Pennsylvania Street**

**Carmel, IN 46032**


**Prepared by:**

**Hermes F. Norero**

Florida Professional Engineer # 73778

Date: 9/8/2023

Contents:  
Evaluation Report      Pages 1 – 4



Hermes F. Norero, P.E.  
Florida No. 73778



FL#: FL16740  
Date: 9/8/2023  
Report No: 8779

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

**Manufacturer:** Allegion-Schlage Lock Company, LLC.

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Doors Assemblies

**Compliance Method:** State Product Approval Method 1(d)

**Product Name:** Outswing Single/Double Flush with Panic Door Hardware (HVHZ)(Impact)

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **Allegion-Schlage Lock Company, LLC.** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Florida Building Code.

See Installation Instructions **F1049DF/F1049SF**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

**Limits of Use:**

1. This product has been evaluated and is in compliance with the Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the Florida Building Code and does not require an impact resistant covering.
4. Site conditions that deviate from the details of Installation Instructions **F1049DF/F1049SF** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **F1049DF/F1049SF** for size and design pressure limitations.



FL#: FL16740  
Date: 9/8/2023  
Report No: 8779

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

**Quality Assurance:** The manufacturer has demonstrated compliance of manufacture products in accordance with the Florida Building Code for manufacturing under a quality assurance program audited by an approved quality assurance entity through **Intertek Testing Services NA, Inc. - QA Entity** (FBC Organization #: QUA1673).

**Performance Standards:** The product described herein has been evaluated per:

- TAS 201-94
- TAS 202-94
- TAS 203-94
- ASTM E1886-13a
- ASTM E1996-14a
- ASTM E330-14

1. Product Testing performed by **Element Materials Technology**  
(FBC Organization # TST2613)  
Report #: ESP011623P, Report Date: 05/15/13  
All reports signed and sealed by Jason Steen, FL P.E. No 67814
2. Quality Assurance Entity:  
**Intertek Testing Services NA Inc. – QA Entity**  
(FBC Organization #: QUA1673)

**Installation:** Refer to Installation Instructions (**F1049DF/F1049SF**) for qualified installation methods and requirements.

**Design Pressure:** Refer to Installation Instructions (**F1049DF/F1049SF**) for design pressures dependent on hardware type, configuration, and size of units.



FL#: **FL16740**  
Date: 9/8/2023  
Report No: 8779

398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

**Equivalence of Test Standards:**

Various test standards have been evaluated for differences in test methodology, if any, between tested editions of the test standards listed below and those editions referenced in the current Florida Building Code. The manufacturer has tested their products to the following test standard edition(s):

- 1) ASTM E1886-05
- 2) ASTM E1996-09
- 3) ASTM E330-02

Chapter 35 of the current Florida Building Code references the following editions of the above mentioned test standards:

- 1) ASTM E1886-13a
- 2) ASTM E1996-14a
- 3) ASTM E330-14

After review of the above-mentioned referenced standards and editions, it has been found that no significant technical changes have been made to the test standards that would affect the results. All referenced standards have been found to be equivalent.