# L. Roberto Lomas P.E.

# **Engineering Evaluation Report**

1432 Woodford Rd. Lewisville, NC 27023 434-688 0609 rllomas@lrlomaspe.com

**Report No.: 513308C** 

**Manufacturer:** Eastern Architectural Systems

16341 Domestic Ave. FT Myers, FL 33912

**Product Line:** Series 176 SS Vinyl Horizontal Sliding Window – XOX – 1/4 - 1/2 - 1/4

#### Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

#### Supporting Technical Documentation:

 Approval document: drawing number 08-02536 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.

2. Test report No.: CTLA 3005W-2A signed and sealed by Ramesh Patel P.E.

Certified Testing Laboratories, Orlando, FL.

AAMA/WDMA/ČSA 101/I.S.2/A440

Design pressure: +50.0/-65.0psf (Through frame installation)

+55.0/-60.0psf (Fin installation)

Water penetration resistance 10.5psf

ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4

Cyclic Load Test, +70.0/-85.0psf (Through frame and fin installation) design pressure

3. Test report No.: CTLA 3005W-2D signed and sealed by Ramesh Patel P.E.

Certified Testing Laboratories, Orlando, FL

**TAS 202** 

Design pressure: +50.0/-65.0psf (Through frame installation)

+55.0/-60.0psf (Fin installation)

Water penetration resistance 10.5psf

TAS 201/TAS203 Large Missile Impact, Level D, Wind Zone 4

Cyclic Load Test, +70.0/-85.0psf (Through frame and fin installation) design pressure

4. Anchor calculations, report number 513308-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

### Limitations and Conditions of use:

• Maximum design pressure: +50.0/-65.0psf (Through frame installation)

+55.0/-60.0psf (Fin installation)

Maximum unit size: 111" X 63"

Approved Configurations: XOX (1/4 – 1/2 – 1/4)

- Units must be glazed per ASTM E1300 according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded vinyl.

## Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02536 Revision B.

#### Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/22/2020