L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688 0609 rllomas@lrlomaspe.com

Report No.: 513310C

Manufacturer:	Eastern Architectural Systems
	16341 Domestic Ave.
	FT Myers, FL 33912

Product Line: Series 176 SS Vinyl Horizontal Sliding Window – XO, OX

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-02537 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
- Test report No.: CTLA 3005W-3A signed and sealed by Ramesh Patel P.E. Certified Testing Laboratories, Orlando, FL AAMA/WDMA/CSA 101/I.S.2/A440 Design pressure: +70.0/-85.0psf Water penetration resistance 10.5psf ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4 Cyclic Load Test, +70.0/-85.0psf design pressure
- Test report No.: CTLA 3005W-3D signed and sealed by Ramesh Patel P.E. Certified Testing Laboratories, Orlando, FL TAS 202 Design pressure: +70.0/-85.0psf Water penetration resistance 10.5psf TAS 201/TAS203 Large Missile Impact, Level D, Wind Zone 4 Cyclic Load Test, +70.0/-85.0psf design pressure
- 4. Anchor calculations, report number 513306-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:


- Maximum design pressure: +70.0/-85.0psf
- Maximum unit size: 74" X 63"
- Approved Configurations: XO, OX
- Units must be glazed per ASTM E1300 according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be extruded vinyl.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02537 Revision B.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/22/2020