

*L. Roberto Lomas P.E.*

400 S. Palm Ave.  
Indialantic, FL 32903  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 514774A

**Manufacturer:** Eastern Architectural Systems  
16341 Domestic Ave.  
Ft Myers, FL 33912

**Product Line:** Series 176 HRP 333 PVB Vinyl Horizontal Sliding Window – XOX

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03658 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: BT-EAS-20-001 signed and sealed by Constantin Bortes P.E.  
Blackwater Technical Services Inc., West Palm Beach, FL  
TAS 201/ TAS 203 Large Missile Impact Test, Level D, Wind Zone 4  
Cyclic Pressure loading  $\pm 60.0$ psf design pressure  
TAS 202 Uniform Static Air Pressure,  $\pm 60.0$ psf design pressure, 9.0psf water penetration.
3. Anchor calculations, report number 514774-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure:  $\pm 60.0$ psf
- Unit size: 110" x 62"
- Units must be glazed per ASTM E1300, according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be rigid PVC.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03658, Revision A.

**Certification of Independence:**

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

