

*L. Roberto Lomas P.E.*

1432 Woodford Rd.  
Lewisville, NC 27023  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 513147C

**Manufacturer:** Wojan Window and Door Corp.  
217 Stover Road  
Charlevoix, MI 49270

**Product Line:** M950 Aluminum Fixed Over Fixed Window – 60" x 99" Non-Impact

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-02378 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Report No.: A8578.01-602-44 signed by Audrey S. Matis  
Architectural Testing Inc., Schofield, WI  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure:  $\pm 75.19$ psf  
Water penetration resistance 12.12psf
3. Anchor calculations, report number 513147-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure:  $\pm 75.0$ psf
- Unit size: 60" x 99"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be aluminum 6063-T6.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02378 Revision B.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

