L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 514834

Manufacturer: Wojan Window & Door Corporation

217 Stover Road Charlevoix, MI 49720

Product Line: Series M950 Thermally Broken Aluminum Fixed Window 60" x 99" Non-Impact

Compliance:

The product mentioned above has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03697, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Report No.: D7720.01-201-44 signed by Daniel A. Johnson

Architectural Testing, Inc. St. Paul, MN
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±90.23psf
Water penetration resistance 15.04psf

3. Anchor calculations, report number 514834-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

Design pressure: ±90.0psfUnit size: ±90.0psf


- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T6.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03697.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 04/01/2021