

**Evaluation Report 1033D**  
August 4, 2023

**Product Description:** Series 8300 PVC Fixed Window, Wind Zone 3 LM Impact, 36" x 72" max. unit size with design pressure of +/-55 psf, and 48" x 60" max. unit size with design pressure of +/-50 psf

**Manufacturer:** Custom Window Systems, Inc. 1900 SW 44<sup>th</sup> Ave, Ocala, FL 34474

**Statement of Compliance:** This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 8<sup>th</sup> Edition (2023) Florida Building Code, not including the High Velocity Hurricane Zone or Wind Zone 4. The product testing standards performed are outlined below.

**Technical Documentation:**

- 1) This report, prepared by Lucas A. Turner, PE, at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Approval drawing CWS-1033D, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports NCTL-210-3949-01/3950-01/3952-01/3953-01, by National Certified Testing Laboratories, Orlando, FL, with testing performed with equivalency to: ASTM E 1886-13a/19, ASTM E 1996-17/20 (large missile impacts in accordance with Wind Zone 3), and AAMA/WDMA/CSA 101/I.S.2/A440-08/11/17
- 4) Supplemental Calculations to support CWS-1033D, signed and sealed by Lucas A. Turner, P.E.

**Installation:** Units must be installed according to approval document CWS-1033D.

**Limitations of Use:** This product:

- May be used in the configurations, up to the sizes and daylight openings, with glazing as indicated in CWS-1033D
- Achieves design pressures as indicated in Product Description above
- Is Large Missile impact resistant (Wind Zone 3) and does not require the use of shutters
- May not be used in the High Velocity Hurricane Zone or Wind Zone 4 areas  
Requires Kuraray Butacite PVB Interlayer
- Requires Quanex or Veka white rigid PVC frame extrusions

**Certification of Independence:** I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Custom Window Systems or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



8/4/2023  
Lucas A. Turner, P.E.  
FL PE #58201