

# R W Building Consultants, Inc.

Consulting and Engineering Services for the Building Industry

P.O. Box 230 Valrico, FL 33595 Phone 813.659.9197

Florida Board of Professional Engineers Registry License No. 9813

## Product Evaluation Report Report No.: FL-17460.1 Date: September 8, 2020

Product Category	Sub Category	Manufacturer	Product Name
Exterior Doors	Swinging Exterior Door Assemblies	Premier Products, Inc. 2840 Sterlington Road Monroe, LA 71203 Phone: (318) 361-0796	"SWR-S18-4" Severe Windstorm Rated Steel Door Outswing "Non-Impact"

**Scope:** Product Evaluation report issued by R W Building Consultants, Inc. & Lyndon F. Schmidt, P.E. (System ID # 1998) for Premier Products, based on Rule Chapter No. 61G20-3, Method 1D of the State of Florida Product Approval, Dept. of Business & Professional Regulation.

RW Building Consultants and Lyndon F. Schmidt, P.E. do not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.


**Limitations:**

- This product has been evaluated and is in compliance with the 7th Edition (2020) Florida Building Code (FBC) structural requirements excluding the "High Velocity Hurricane Zone" (HVHZ).
- Product anchors shall be as listed and spaced as shown on details. Anchor embedment to base material shall be beyond wall dressing or stucco.
- When used in areas requiring wind borne debris protection this product is required to be protected with an impact resistant covering that complies with FBC Sections 1609.1.2 & R301.2.1.2.
- Site conditions that deviate from the details of drawing FL-17460.1 require further engineering analysis by a licensed engineer or registered architect.
- See drawing FL-17460.1 for size and design pressure limitations.

**Supporting Documents:**

- |  |   |  |  |
|--|---|--|--|
| 1. <u>Test Report No.</u><br>ATI 69046.01-201-44 | <u>Test Standard</u><br>ASTM E 330-02                       | <u>Testing Laboratory</u><br>Architectural Testing, Inc. | <u>Signed by</u><br>Daniel A. Johnson, P.E.              |
| 2. <u>Drawing No.</u><br>No. FL-17460.1          | <u>Prepared by</u><br>RW Building Consultants, Inc. (#9813) |  | <u>Signed &amp; Sealed by</u><br>Lyndon F. Schmidt, P.E. |
| 3. <u>Calculations</u><br>Anchoring              | <u>Prepared by</u><br>RW Building Consultants, Inc. (#9813) |  | <u>Signed &amp; Sealed by</u><br>Lyndon F. Schmidt, P.E. |

- Quality Assurance**  
Certificate of Participation issued by National Accreditation and Management Institute, certifying that Premier Products is manufacturing products within a quality assurance program that complies with ISO/IEC 17020 and Guide 53.



Lyndon F. Schmidt, P.E.  
FL PE No. 43409  
9/8/2020