12781 Miramar Pkwy. Ste. 301 Miramar, FL. 33027 P: 305 271-0117 F: 305 279-6818

PRODUCT APPROVAL EVALUATION REPORT

| <u>Product Manufacturer:</u> | Product Name/Model & Description: | |
|---|--|--|
| NCCL Corporation, Inc. GSS-1 Genesis Shutter System | | |
| 9960 NW 79 th Ave. | GSS-1 Genesis Aluminum Accordion Shutter | |
| Hialeah Gardens, FL 33016 | System – 1 Magnum | |
| | Accordion Shutter System (LMI & SMI) | |

Scope: This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

Code: 6th **Edition Florida Building Code (2017)**, inclusive of all Supplements effective as of this report date.

Compliance Method: 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer

Product Description: Product Approval **Drawing #AD15-11 & #AD20-15**, prepared by MCY Engineering, signed and sealed by Yiping Wang, P.E., is an integral part of this Evaluation Report.

Limitations & Conditions of Use:

- This product has been evaluated for use **inside and outside of the HVHZ** (High Velocity Hurricane Zone)
- Impact Resistance: Large and Small Missile Impact
- Refer to Product Approval Drawing noted above for:
 - Maximum allowable wind loads at related maximum allowable size(s).
 - Other load limitations applicable to the product, if any.
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - o Illustrated diagrams of the attachment of the product to the structure.
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.

Test Reports:

12781 Miramar Pkwy. Ste. 301 Miramar, FL. 33027 P: 305 271-0117

F: 305 279-6818

Mandatory Tests (Tested in accordance with AAMA 501)

| Test Lab | Report Number | Test Report Date | Test Standard & Description |
|--|----------------------|------------------|--|
| Hurricane engineering & Testing, INC-Doral, FL | HELTI-13-4028, | 06/18/13 | ASTM E330 (static load test) TAS 202 (uniform static test) |
| | 4030, 4032, 4034, | | |
| | 4036, 4038, 4050, | | |
| | 4053 signed and | | |
| | sealed by Rafael E. | | |
| | Droz- Seda, PE | | |
| Hurricane engineering & Testing, Inc-Doral, FL | HELTI-13-4029, | 06/18/13 | TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E1886 (cyclic wind pressure loading) ASTM E1996 (large missile impact) |
| | 4031, 4033, 4035, | | |
| | 4037, 4039, 4051, | | |
| | 4054, signed and | | |
| | sealed by Rafael E. | | |
| | Droz- Seda, PE | | |
| Hurricane engineering & Testing, Inc-Doral, FL | HELTI-20-8002, | 03/20/20 | ASTM E330 (static load test) |
| | 8004, 8006, 8008, | | TAS 202 (uniform static test) |
| | 8011, 8013, signed | | |
| | and sealed by Rafael | | |
| | E. Droz- Seda, PE | | |
| Hurricane engineering & Testing, Inc-Doral, FL | HELTI-20-8003,8005, | 03/20/20 | TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E1886 (cyclic wind pressure loading) |
| | 8007, 8009, 8013, | | |
| | 8014, signed and | | |
| | sealed by Rafael E. | | ASTM E1996 (large missile impact) |
| | Droz- Seda, PE | | |

Engineering Analysis: The following engineering analyses and/or calculations have been performed

No comparative analysis has been performed for conditions other than those tested.

No rational analysis has been performed.

Anchor calculations are based on manufacturer's published anchor capacity, anchor Notice Acceptance by Miami Dade County Acceptance by Miami Dade County.

May 26th, 2020