

## PRODUCT APPROVAL EVALUATION REPORT

<p><u>Product Manufacturer:</u> <b>NCCL Corporation, Inc.</b> 9960 NW 79<sup>th</sup> Ave. Hialeah Gardens, FL 33016</p>	<p><u>Product Name/Model &amp; Description:</u> <b>GSS-1 Genesis Aluminum Accordion Shutter System – 1 Magnum</b> Accordion Shutter System (LMI &amp; SMI)</p>
--	--

**Scope:** This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

**Code:** 8<sup>th</sup> Edition Florida Building Code (2023), inclusive of all Supplements effective as of this report date.

**Compliance Method:** 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer


**Product Description:** Product Approval Drawing #AD20-15 & AD15-11, prepared by MCY Engineering, signed and sealed by Yiping Wang, P.E., is an integral part of this Evaluation Report.

**Limitations & Conditions of Use:**

- This product has been evaluated for use **inside and outside of the HVHZ** (High Velocity Hurricane Zone)
- Impact Resistance: **Large and Small Missile Impact**
- Refer to Product Approval Drawing noted above for:
  - Maximum allowable wind loads at related maximum allowable size(s).
  - Other load limitations applicable to the product, if any.
  - Overall dimensions and material/grade of main product components, accessories, etc.
  - Illustrated diagrams of the attachment of the product to the structure.
  - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.



January 31st, 2024



**Test Reports:**

**Mandatory Tests (Tested in accordance with AAMA 501)**

Test Lab	Report Number	Test Report Date	Test Standard & Description
Hurricane engineering & Testing, Inc-Doral, FL	HELTI-20-8002, 8004, 8006, 8008, 8011, 8013, signed and sealed by Rafael E. Droz- Seda, PE	03/20/20	ASTM E330 (static load test) TAS 202 (uniform static test)
Hurricane engineering & Testing, Inc-Doral, FL	HELTI-20-8003,8005, 8007, 8009, 8013, 8014, signed and sealed by Rafael E. Droz- Seda, PE	03/20/20	TAS 201 (large missile impact) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E1886 (cyclic wind pressure loading) ASTM E1996 (large missile impact)
Hurricane engineering & Testing, INC-Doral, FL	HELTI-13-4028, 4030, 4032, 4034, 4036, 4038, 4050, 4053 signed and sealed by Rafael E. Droz- Seda, PE	06/18/13	ASTM E330 (static load test) TAS 202 (uniform static test)
Hurricane engineering & Testing, Inc-Doral, FL	HELTI-13-4029, 4031, 4033, 4035, 4037, 4039, 4051, 4054, signed and sealed by Rafael E. Droz- Seda, PE	06/18/13	TAS 201 (large missile impact) TAS 202 (uniform static test) TAS 203 (cyclic wind pressure loading) ASTM E1886 (cyclic wind pressure loading) ASTM E1996 (large missile impact)

**Engineering Analysis:** The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer's published anchor capacity, anchor spacing, and acceptance by Miami Dade County.



January 31st, 2024