

Force Engineering & Testing

19530 Ramblewood Drive
Humble, Texas 77338
Phone: (281) 540-6603 FAX: (281) 540-9966
Website: www.forceengineeringtesting.com

Product Evaluation Report
WHIRLWIND STEEL BUILDINGS, INC.

24 Ga. Weather Lok Roof Panel over Steel Deck

Florida Product Approval # 17704.3 R4


Florida Building Code 2023
Per Rule 61G20-3
Method: 1 -D

Category: Roofing
Subcategory: Metal Roofing
Compliance Method: 61G20-3.005(1)(d)
NON HVHZ

Product Manufacturer:
Whirlwind Steel Buildings, Inc.
8234 Hansen Road
Houston, TX 77075


Engineer Evaluator:
Johnathan Green, P.E. #88223
Florida Evaluation ANE ID: 12901

Contents:
Evaluation Report: Page 1 - 3
Installation Detail: Page 4



THIS DOCUMENT HAS BEEN DIGITALLY SIGNED AND SEALED BY JOHNATHAN GREEN ON THE DATE ADJACENT TO THE SEAL.

PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.



Force Engineering & Testing

19530 Ramblewood Drive
Humble, Texas 77338

Phone: (281) 540-6603 FAX: (281) 540-9966
Website: www.forceengineeringtesting.com

Compliance Statement: The product as described in this report has demonstrated compliance with the Florida Building Code 2023, Sections 1504.3.2.

Product Description: Weather Lok Min. 24 Ga. Steel, 16" Wide, standing seam roof panel over 22 Ga. Steel deck. Non-Structural Application.

Panel Material/Standards: Material: Minimum 24 Ga. Steel, ASTM A792 or ASTM A653 G90 conforming to Florida Building Code 2023 Section 1507.4.3. Paint finish optional
Yield Strength: Min. 50.0 ksi
Corrosion Resistance: Panel Material shall comply with Florida Building Code 2023, Section 1507.4.3.

Panel Dimension(s): Thickness: 0.023"
Width: 16" Maximum Coverage
Rib: 2" tall
Panel Seam: Triple lock with mechanical seamer

Roof Panel Clips: Product Name: MC1203 Sliding Clip
Type: Top: 22 Ga. steel, Base: 16 Ga. Steel
Corrosion Resistance: Per Florida Building Code 2023 Section 1506.7

Clip Bearing Plate: 4"x5" 16 Ga. steel
Corrosion Resistance: Per Florida Building Code 2023 Section 1506.7

Roof Clip Fastener: (2) #14-13 Deck Screw
3/4" minimum penetration through steel deck
Corrosion Resistance: Per Florida Building Code 2023, Section 1507.4.4.

Substrate Description: Min. 22 Ga. Steel Deck. Substrate must be designed in accordance w/ Florida Building Code 2023.

Allowable Design Uplift Pressures:


Table "A"

Maximum Total Uplift Design Pressure:	63.5 psf	161.0 psf
Clip Spacing:	48" O.C.	12" O.C.

*Design Pressure includes a Safety Factor = 2.0.



Code Compliance:	The product described herein has demonstrated compliance with The Florida Building Code 2023, Section 1504.3.2.
Evaluation Report Scope:	The product evaluation is limited to compliance with the structural wind load requirements of the Florida Building Code 2023, as relates to Rule 61G20-3.
Performance Standards:	The product described herein has demonstrated compliance with: <ul style="list-style-type: none">▪ UL 580-06 - Test for Uplift Resistance of Roof Assemblies▪ UL 1897-2015 - Uplift Test for Roof Covering Systems
Reference Data:	<ol style="list-style-type: none">1. UL 580-06 / 1897-2012 Uplift Test Force Engineering & Testing, Inc. (FBC Organization # TST-5328) Report No. 14-0164T-17A, B2. Certificate of Independence By Johnathan Green, P.E. (No. 88223) @ Force Engineering & Testing (FBC Organization # ANE ID: 12901)
Test Standard Equivalency:	<ol style="list-style-type: none">1. The UL 1897-2012 test standard is equivalent to the UL 1897-2015 test standard.
Quality Assurance Entity:	The manufacturer has established compliance of roof panel products in accordance with the Florida Building Code and Rule 61G20-3.005 (3) for manufacturing under a quality assurance program audited by an approved quality assurance entity.
Minimum Slope Range:	Minimum Slope shall comply with Florida Building Code 2023, including Section 1507.4.2 and in accordance with Manufacturers recommendations.
Installation:	Install per manufacturer's recommended details.
Underlayment:	Per Florida Building Code 2023 and manufacturer's installation guidelines.
Insulation:	6" maximum thickness, polyisocyanurate foamed plastic with min. 20 psi compressive strength.
Roof Panel Fire Classification:	Fire classification is not part of this acceptance.
Shear Diaphragm:	Shear diaphragm values are outside the scope of this report.
Design Procedure:	Based on the dimensions of the structure, appropriate wind loads are determined using Chapter 16 of the Florida Building Code 2023 for roof cladding wind loads. These component wind loads for roof cladding are compared to the allowable pressure listed above. The design professional shall select the appropriate erection details to reference in his drawings for proper fastener attachment to his structure and analyze the panel fasteners for pullout and pullover. Support framing must be in compliance with Florida Building Code 2023 Chapter 22 for steel, Chapter 23 for wood and Chapter 16 for structural loading.



Force Engineering & Testing

19530 Ramblewood Drive
Humble, Texas 77338

Phone: (281) 540-6603 FAX: (281) 540-9966
Website: www.forceengineeringtesting.com

