



Product Manufacturer:
Enviralum Industries INC.
5110 N.W. 72 AVENUE BLDG. C
Miami, FL. 33166

<u>Product Name/Model & Description:</u>
ENV-450 Aluminum Window Wall System- L.M.I

-Large missile impact

## PRODUCT APPROVAL EVALUATION REPORT

**Scope:** This product has been evaluated by the below-signed Florida Professional Engineer for compliance with the Code noted herein and is, for the purpose intended, at least equivalent to that required by the Code, in accordance with section 553.842 F.S. & chapter 61G20-3.005 F.A.C. Re-evaluation of this product shall be required following applicable Code modifications or revisions.

**Code: 7**<sup>th</sup> **Edition Florida Building Code (2020)**, inclusive of all Supplements effective as of this report date.

**Compliance Method:** 61G20-3.005 (1)(d) – Evaluation Report from a licensed Professional Engineer

**Product Description:** Product Approval **Drawing #AD20-39** prepared by MCY Engineering, signed and sealed by Yiping Wang P.E., is an integral part of this Evaluation Report.

## **Limitations & Conditions of Use:**

- This product has been evaluated for use inside and outside of the HVHZ (High Velocity Hurricane Zone)
- Impact Resistance: Large Missile Impact
- Refer to Product Approval Drawing noted above for:
  - Maximum allowable wind loads at related maximum allowable size(s).
  - Other load limitations applicable to the product, if any.
  - o Overall dimensions and material/grade of main product components, accessories, etc.
  - o Illustrated diagrams of the attachment of the product to the structure.
  - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.

## **Test Reports:**

## Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS-02/TAS-202)

Test Lab	Report Number	Test Report Date	Test Standard & Description
Blackwater Testing, Inc. West Palm Beach, FL 33413	BT-ENI-16-003 BT-ENI-16-003B signed and sealed by Constantin Bortes, PE	06/19/17	TAS 201 (large missile impact) TAS 203 (cyclic wind pressure loading) ASTM E1886/E1996(Large Missile Impact &Cyclic Level D/E)
Fenestration Testing Laboratory FL33166	FTL-6678 signed and sealed by Marlin Brinson,PE	04/23/12	TAS 202 (uniform static test) ASTM E331 OR ASTM 547 (Water Penetration) ASTM E283 (Air Infiltration Leakage) ASTM E330 & TAS 202 (Uniform Static Air Press)

**Engineering Analysis:** The following engineering analyses and/or calculations have been performed:

- No comparative analysis has been performed for conditions other than those tested.
- No rational analysis has been performed.
- Anchor calculations are based on manufacturer's published anchor capacity, anchor Notice of Acceptance by Miami Dade County.



December 30th, 2020