

L. Roberto Lomas P.E.

1432 Woodford Rd
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 513639A

Manufacturer: Nan-Ya Plastics Corporations U.S.A.
8989 North Loop East
Houston, TX 77029

Product Line: Series "Outswing Side Hinged Door" Opaque Fiberglass 3'0 x 6'8 - LMI

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-02841, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL 210-4002-02 signed by Mark Bennett.
National Certified Testing Laboratories, Orlando, FL.
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±50.0psf
Water penetration resistance 7.5psf
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4
Cyclic Load Test, ±50.0psf design pressure
3. Anchor calculations, report number 513639-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±50.0psf
- Maximum unit size: 37 3/8" x 81 3/16"
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be foam PVC Co-Ex.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02841.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

