

## ENGINEERING EXPRESS® (EX) PRODUCT EVALUATION REPORT

October 19, 2023

Application Number: FL 19588.5  
EX Project Number: 23-68298  
  
Product Manufacturer: Trane Technologies  
Manufacturer Address: 6200 Troup Highway  
Tyler, TX 75707, USA

Product Name & Description: American Standard Units

### ***Scope of Evaluation:***

This Product Evaluation Report is being issued in accordance with the requirements of the Florida Department of Business and Professional Regulation (Florida Building Commission) Rule Chapter 61G20-3.005, F.A.C., for statewide acceptance per Method 2 (b). The product noted above has been tested and/or evaluated as summarized herein to show compliance with standard ASCE 7-22 (ASD) and the Florida Building Code Eighth Edition (2023) and is, for the purpose intended, at least equivalent to that required by the Standard and Code. Re-evaluation of this product shall be required following pertinent Florida Building Code or ASCE Standard modifications or revisions.

### ***Substantiating Data:***

- **PRODUCT EVALUATION DOCUMENTS**

EX Performance Evaluation document # 23-68298 titled "AMERICAN STANDARD UNITS", prepared by Engineering Express, Inc., signed & sealed by Frank Bennardo, P.E. is an integral part of this Evaluation Report, pages 1 through 6.

- **STRUCTURAL ENGINEERING CALCULATIONS**

Structural engineering calculations have been prepared which evaluate the product based on comparative and/or rational analysis to qualify the following design criteria (per FBC 8<sup>th</sup> Ed. 2023 Section 104.11.1):

1. Minimum Allowable Unit Width
2. Maximum Allowable Unit Height
3. Minimum Unit Weight
4. Tie-Down Configuration and Anchor Spacing
5. Anchor Capacity for Various Substrates

### ***Impact Resistance:***

Impact Resistance has not been demonstrated.

Trane Technologies – American Standard Units

### ***Wind Load Resistance:***

This product has been designed to resist wind loads as indicated on its respective Performance Evaluation document (i.e. engineering document).

### ***Installation:***

The product listed above shall be installed in strict compliance with the Performance Evaluation document (i.e. engineering document), along with all components noted therein.

The product components shall be of the material specified in the Performance Evaluation document (i.e. engineering document).

### ***Limitations & Conditions of Use:***

Use of each product shall be in strict accordance with its respective Performance Evaluation document (i.e. engineering document) as noted herein.

All supporting host structures shall be designed to resist all superimposed loads and shall be of a material listed in each product's respective anchor schedule. Host structure conditions which are not accounted for in each product's respective anchor schedule shall be designed for on a site-specific basis by a registered professional engineer.

All components which are permanently installed shall be protected against corrosion, contamination, and other such damage at all times. Any alteration to the respective Performance Evaluation document will invalidate it. This product has been designed for use inside and outside of the High Velocity Hurricane Zone (HVHZ & NON-HVHZ).

Respectfully,

---

Frank Bennardo, P.E.

**ENGINEERING EXPRESS®**

#PE0046549 | Cert. Auth. 9885