

Product Evaluation Report

Rule 61G20-3 F.A.C. | Report No. 2527, Rev. 3 | Project No. 420-0809 | 10/27/20 | Page 1 of 2

Product Manufacturer

Regency Plus Incorporated
2000 Locust Gap Highway
Mount Carmel, PA 17851

Product Name, Model and/or Description

7313 Vinyl Tilt Double Hung Window

Florida Product Approval No.: FL20129

Code: Current Edition of the Florida Building Code including the 7th Edition (2020) Florida Building Code

Compliance Method: Product Approval Rule 61G20-3.005(1)(a) – Certification Mark or Listing

Product Name, Model and/or Designation; Test Report No.; and Installation Drawing No.:

- 7313 Vinyl Tilt Double Hung Window
 - Test reports and associated laboratory drawings by National Certified Testing Laboratories, York, PA.
 - NCTL-110-15925-1, AAMA/WDMA/CSA 101/I.S.2/A440-05 & 08
 - PTC Product Design Group Drawing No. RPLS0070, First Issue, dated 1/11/18, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752
- 7313 Vinyl Tilt Double Hung Window Through Jamb Anchoring
 - Test reports and associated laboratory drawings by National Certified Testing Laboratories, York, PA.
 - NCTL-110-21510-1, AAMA/WDMA/CSA 101/I.S.2/A440-11
 - PTC Product Design Group Drawing No. RPLS0070, Rev. A, dated 10/25/18, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752

Engineering Analysis & Evaluation:

- Anchorage engineering (PTC Calc No. 2527) in accordance with the current edition of the Florida Building Code for 7313 Vinyl Tilt Double Hung Window signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752.
- Frame Profile Substitution per PTC Product Design Group Comparative Analysis Report No. 2594-11, Rev. 0, signed and sealed by Robert J. Amoruso, P.E., FL License Number 49752.
 - Evaluation formed basis for NAMI Waiver of Retest for frame profile substitution.

Component Approvals: Extrusion code conformance based on the following.

- Extruded rigid PVC by Energi Fenestration Solutions USA, Inc. per current Miami-Dade NOA to the current edition of the Florida Building Code. See Miami-Dade NOA listing [here](#).

Performance Testing:

- Performance Standards used in testing:
 - AAMA/WDMA/CSA 101/I.S.2/A440-08 & 11

Limitations & Conditions of Use:

- This product has not been evaluated for use inside the High Velocity Hurricane Zone (HVHZ).
- This product will require an approved impact protective system when used in wind borne debris regions.
- Refer to Product Installation Instructions noted above for:
 - Maximum allowable wind loads at related maximum allowable size(s).
 - Overall dimensions and material/grade of main product components, accessories, etc.
 - Illustrated diagrams of the attachment of the product to substrate structure.
 - Anchor type(s), size(s), substrate(s), embedment, edge distance, and spacing/locations.



Product Evaluation Report


Rule 61G20-3 F.A.C. | Report No. 2527, Rev. 3 | Project No. 420-0809 | 10/27/20 | Page 2 of 2

- Site wind pressures shall be determined by a licensed professional engineer in accordance with the current edition of the Florida Building Code (and/or ASCE 7 as referenced in the current edition of the Florida Building Code) for components and cladding based on allowable stress design.
- Site conditions not covered in this product evaluation document are subject to additional engineering analysis by a licensed professional engineer or registered architect as required by the authority having jurisdiction.
- Adequacy of the existing structural substrates as a main wind force resisting system capable of withstanding and transferring applied product loads to the foundation is the responsibility of the licensed professional engineer or registered architect acting as the design professional of record for the project of installation.

Certificate of Independence per Product Approval Rule 61G20-3.009

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. does not have, nor will acquire, any financial interest in the company manufacturing or distributing product(s) covered by this Product Evaluation Report.

PTC Product Design Group, LLC and Robert J. Amoruso, P.E. do not have, nor will acquire any financial interest in any other entity involved in the approval process or testing of the product(s) covered by this Product Evaluation Report.



Digitally signed
by Robert J
Amoruso
Date:
2020.10.27
17:27:04 -04'00'

Evaluated By:
Robert J. Amoruso, P.E.
FL P.E. License Number 49752

Evaluated By:
Robert J. Amoruso, P.E.
FL P.E. License Number 49752

