### L. Roberto Lomas P.E.

# **Engineering Evaluation Report**

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

**Report No.: 513877A** 

**Manufacturer:** Nan Ya Plastics Corporation

8989 North Loop East Houston, TX 77029

Product Line: Series "MK-3" Fiberglass Skin Glazed Entry Door Inswing w/ or w/o Sidelites - Impact HVHZ

### Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

### Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03012, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: ETC-07-255-18448.5 signed and sealed by Joseph Labora Doldan, P.E.

ETC Laboratories, Rochester, NY

TAS 201 Large Missile Impact Test, Level D, Wind Zone 4

TAS 202 Uniform Static Air Pressure: ±50.0psf design pressure, 3.0psf water penetration.

TAS 203 Cyclic Pressure loading, ±50.0psf design pressure

3. Test report ETC-05-255-16776.1 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Fiberglass testing

ASTM D2843	Smoke density	52.1%
ASTM D635	Rate of burning	C1
ASTM D1929	Self ignition temperature	1060 °F
ASTM D638	Tensile strength unexposed	11,860 psi
	Tensile strength Xenon arc exposed	11,063 psi

4. Test report ETC-05-255-16777.1 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Cellular PVC testing

ASTM D2843	Smoke density	49.6%
ASTM D635	Rate of burning	C1
ASTM D1929	Self ignition temperature	950 °F
ASTM D638	Tensile strength unexposed	6,019 psi
	Tensile strength Xenon arc exposed	6,014 psi

5. Test report ETC-05-255-17144-7 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Rigid PVC testing

	9	
ASTM D2843	Smoke density	37.4%
ASTM D635	Rate of burning	C1
ASTM D1929	Self ignition temperature	900 °F
ASTM D638	Tensile strength unexposed	6,140 psi
	Tensile strength Xenon arc exposed	6 053 psi

6. Test report ETC-06-255-17412.1 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Phenolic Foam testing

ASTM E84 Flame spread index 10 Smoke developed index 95


7. Test report ETC-06-255-17900.0 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Phenolic Foam testing

ASTM D1929 Self ignition temperature 1100 °F

8. Anchor calculations, report number 513877-1, prepared, signed and sealed by Luis Roberto Lomas P.E.



Luis R. Lomas, P.E. FL No.: 62514 10/06/2020

## L. Roberto Lomas P.E.

## **Engineering Evaluation Report**

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

**Report No.: 513877A** 

### Limitations and Conditions of use:

Maximum design pressure: +20.0/-50.0psf
Maximum panel size: +20.0/-50.0psf
35 ¾" x 79 ¼"

• Approved configurations: O/XX/O, O/XX, XX/O, XX, O/X/O, O/X, X/O, X.


- Units must be glazed per ASTM E1300 see installation instructions for glass details.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be cellular PVC.

#### Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document, 08-03012.

### Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/06/2020