



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 E Dania Beach Blvd.  
Suite 338  
Dania Beach, FL 33004  
954.399.8478 PH  
954.744.4738 FX  
contact@buildingdrops.com

## Product Evaluation Report

*of*

**JELD-WEN, inc.  
Premium Vinyl (V4500) Multi-Slide Patio Door  
Wind Zone 3 Impact Rated**

*for*

**Florida Product Approval**

**Report No. 6737**


### Current Florida Building Code

<b>Method:</b>	<b>1 – A (Certificate Method)</b>
<b>Category:</b>	<b>Exterior Doors</b>
<b>Sub – Category:</b>	<b>Sliding Exterior Door Assemblies</b>
<b>Product:</b>	<b>Premium Vinyl Multi-Slide Patio Door – SGP 6-Panel 4-Track XXXXXX Pocket Jamb</b>
<b>Material:</b>	<b>Vinyl</b>

**Prepared for:**  
**JELD-WEN, inc.**  
**3737 Lakeport Blvd.**  
**Klamath Falls, OR 97601**

**Prepared by:**  
**Hermes F. Norero, P.E.**  
Florida Professional Engineer # 73778  
Date: 04/01/2020

Contents:  
Evaluation Report      Pages 1 – 3



Hermes F. Norero, P.E.  
Florida No. 73778



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 04/01/2020

Report No: 6737

---

**Manufacturer:** JELD-WEN, inc.

**Product Category:** Exterior Doors

**Product Sub-Category:** Sliding Exterior Door Assemblies

**Compliance Method:** State Product Approval Method (1)(a)

**Product Name:** Premium Vinyl Multi-Slide Patio Door– SGP  
6-Panel 4-Track XXXXXX Pocket Jamb

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **JELD-WEN, inc.** based on Method 1a of the State of Florida Product Approval, Florida Department of Business & Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **D014907**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

## Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the “High Velocity Hurricane Zone” (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does not** require an impact resistant covering in Wind Zones 3 or less.
4. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does** require an impact resistant covering in Wind Zone 4.
5. Site conditions that deviate from the details of drawing **D014907** require further engineering analysis by a licensed engineer or registered architect.
6. See Installation Instructions **D014907** for size and design pressure limitations.

Hermes F. Norero, P.E.

Florida No. 73778

Page 2 of 3



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 04/01/2020

Report No: 6737

**Certification Agency:** The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a program audited by and approved by **American Architectures Manufactures Association** (FBC Organization #: CER1498).

**Performance Standards:** The product described herein has been evaluated per:

- AAMA/WDMA/CSA 101/I.S.2/A440-08
- AAMA 506-16
- ASTM E1886-13
- ASTM E1996-14

**Referenced Data:**

1. Product Testing performed by **National Testing Laboratories, Inc.** (FBC Organization # TST1589)  
Report: NCTL-110-16-131, Report Date: 02/02/2017  
Report: NCTL-SJW2016-009, Report Date: 04/26/2016  
Report: NCTL-110-16-141, Report Date: 04/12/2017
2. Certification Agency  
**American Architectures Manufactures Association**  
(FBC Organization #CER1773)

**Installation:**

Refer to Installation Instructions (**D014907**) for anchor spacing and more details of the installation requirements.

**Design Pressure:**

Refer to Installation Instructions (**D014907**) for design pressures, sizes, and configurations.