



# AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

## PRODUCT APPROVAL EVALUATION RULE CHAPTER #61G20-3 • METHOD 1 OPTION D

FL 21906

Date: 06/03/2021

### Detailed Product Description:

**Manufacturer:** PORCELANOSA

**Manufacturer Address:** 8700 NW 13 TERRACE – MIAMI, FL 33172

**Model Name:** PORCELAIN PANEL, BY PORCELANOSA GRUPO - RAINSCREEN VENTILATED FACADE SYSTEM

**Maximum Load:** +80 PSF, -80 PSF (Non-Impact)

**Installation Drawings #** 17-0153

This product complies with the High Velocity Hurricane Zone (HVHZ) testing requirements.

For maximum sizes, combination of span vs loads and anchor type refer to installation drawings.

Comparative analysis used ☐ Yes ☒ No

### Mandatory Tests (Tested in accordance with AAMA 101/I.S.2/NAFS/TAS-202)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
ASTM E330 & TAS 202	Uniform Static Air Press.	Architectural Testing	09/14/2016 01/05/2017	F4240.01-109-18 G4233.01-109-18	Charles L. Anderson, PE

### Supplemental Tests (Tested in accordance with TAS-203)

TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	Test Sealed by
TAS 203	Cyclic	Architectural Testing	09/14/2016 01/05/2017	F4240.01-109-18 G4233.01-109-18	Charles L. Anderson, PE

Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.

### Evaluation Report Engineer:

Jalal Farooq  
Al-Farooq Corporation  
PE # 81223  
EB # 3538



Sealed: 6/9/2021