

BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 E Dania Beach Blvd. Suite 338 Dania Beach, FL 33004 954.399.8478 PH 954.744.4738 FX contact@buildingdrops.com

Product Evaluation Report

of

JELD-WEN, inc. Premium Vinyl Stationary Insash Casement Window Impact Rated

for

Florida Product Approval

Report No. 5384

Current Florida Building Code

Method: Category: Sub – Category:

Product Dimensions:

1 – A (Certificate Method) Windows Fixed

Product:

Material:

Premium Vinyl Stationary Insash Casement Impact– WZ2 Vinyl 36" x 72"

Prepared For:

JELD-WEN, inc. 3737 Lakeport Blvd. Klamath Falls, OR 97601

Prepared by: Hermes F. Norero, P.E. Florida Professional Engineer # 73778 Date: 12/14/2017

Contents: Evaluation Report Pages 1 – 3





Product Name:	Premium Vinyl Stationary Insash Casement Impact – WZ2
Compliance Method:	State Product Approval Method (1)(a)
Product Sub-Category:	Fixed
Product Category:	Windows
Manufacturer:	JELD-WEN, inc.

Scope:This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for JELD-WEN, inc.
based on Method 1a of the State of Florida Product Approval, Florida Department of Business &
Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **D014455**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

Limits of Use:

- 1. This product has been evaluated and is in compliance with the current Florida Building Code, <u>excluding</u> the "High Velocity Hurricane Zone" (HVHZ).
- 2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
- 3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and <u>does not</u> require an impact resistant covering in Wind Zones 3 or less.
- 4. Site conditions that deviate from the details of drawing **D014455** require further engineering analysis by a licensed engineer or registered architect.
- 5. See Installation Instructions **D014455** for size and design pressure limitations.

Hermes F. Norero, P.E. Florida No. 73778 Page 2 of 3



Certification Agency:	Florida	ufacturer has demonstrated compliance of products in accordance with the uilding Code for manufacturing under a program audited by and approved ican Architectural Manufactures Association (FBC Organization #: 8).		
Performance Standards:	The product described herein has been tested per:			
	• AA	AAMA/WDMA/CSA/I.S.2/A440-08/11		
	• AS	TM E1886-05		
	• AS	STM E1996-09		
Referenced Data:	1.	Product Testing performed by National Certified Testing Laborator (FBC Organization # TST1589)	ies.	
		Report: 110-17-047, Report Date: 03/10/2017		
	2.	Certification Agency American Architectural Manufactures Association (FBC Organization #CER1498)		

Installation:

Refer to Installation Instructions (**D014455**) for anchor spacing and more details of the installation requirements.

Design Pressure:

Configuration	Size	Design Pressure
0	36" x 72"	+50/-55 PSF