L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 513841A

Manufacturer: Nan Ya Plastics Corp.

8989 North Loop East Houston, TX 77029

Product Line: Series SPLS Gliding Patio Door

Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

- 1. Approval document: drawing number 08-02988, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: NCTL 210-3821-6 signed and sealed by Gerard J. Ferrara, P.E.

National Certified Testing Laboratories, Orlando, FL

TAS 201 Large Missile Impact Test, Level D, Wind Zone 4

TAS 202 Uniform Static Air Pressure, ±50.0psf design pressure, water penetration: 7.5psf (without sill riser), 9.75psf (with sill riser)

TAS 203 Cyclic Pressure loading ±50.0psf design pressure

3. Test report ETC-05-255-16776.1 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Fiberglass testing

ASTM D2843 Smoke density 52.1%
ASTM D635 Rate of burning C1
ASTM D1929 Self ignition temperature 1060 °F
ASTM D638 Tensile strength unexposed 11,860 psi
Tensile strength Xenon arc exposed 11,063 psi

Test report ETC-05-255-16777.1 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Cellular PVC testing

ASTM D2843 Smoke density 49.6%
ASTM D635 Rate of burning C1
ASTM D1929 Self ignition temperature 950 °F
ASTM D638 Tensile strength unexposed 6,019 psi
Tensile strength Xenon arc exposed 6,014 psi


5. Test report ETC-05-255-17144-7 signed and sealed by Joseph Labora Doldan P.E.

ETC Laboratories, Rochester, NY

Rigid PVC testing

ASTM D2843 Smoke density 37.4%
ASTM D635 Rate of burning C1
ASTM D1929 Self ignition temperature 900 °F
ASTM D638 Tensile strength unexposed 6,140 psi
Tensile strength Xenon arc exposed 6,053 psi

 Anchor calculations, report number 513841-1, prepared, signed and sealed by Luis Roberto Lomas P.E.



Luis R. Lomas, P.E. FL No.: 62514 10/07/2020

L. Roberto Lomas P.E.

Engineering Evaluation Report

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 513841A

Limitations and Conditions of use:

Maximum design pressure: ±50.0psf (with and without sill riser)

• Maximum panel size: 35 3/4" x 79 1/4"

Approved Configurations: OXXO, OXX, XXO, XX, OX, XO.


- Units must be glazed per ASTM E1300 according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Foam PVC Co-Ex.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-02988.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 10/07/2020