



NATIONAL CERTIFIED TESTING LABORATORIES

FIVE LEIGH DRIVE • YORK, PENNSYLVANIA 17406 • TELEPHONE (717) 846-1200
FAX (717) 767-4100
www.nctlinc.com

PRODUCT APPROVAL SUPPORTING CALCULATIONS

Premium Vinyl Horizontal Sliding Window

REPORT TO:

**JELD-WEN WINDOWS & DOORS
3737 LAKEPORT BLVD
KLAMATH FALLS, OREGON**

REPORT NUMBER: NCTL-110-23985-11
REPORT DATE: 02/04/21

Joseph A. Reed, PE
FL PE 58920
FL REG 33474



Scope

National Certified Testing Laboratories was contracted by Jeld-Wen Windows & Doors to evaluate alternate installation methods for their Premium Vinyl Horizontal Sliding windows. The evaluation is based on physical testing and product certifications. Reference standards utilized in this project include:

Florida Building Code, Building. International Code Council.

ANSI/AWC National Design Specification (NDS) for Wood Construction. American Wood Council.

AISI S100 North American Specification for the Design of Cold-Formed Steel Structural Members. American Iron and Steel Institute.

ICC-ES Report ESR-1976 ITW Buildex TEKS Self-Drilling Fasteners. ICC Evaluation Service.

NOA 16-1222.06 Tapcon Concrete and Masonry Anchors with Advanced Threadform Technology. Miami-Dade County Product Control Section.

The anchorage analyses presented herein do not address the water resistance, water penetration or air infiltration performance of the installation method or the installed product. In addition, the analyses rely on the assumption that the building substrate is capable of withstanding incurred loads.

Certification of Independence

In accordance with Rule 61G20-3 Florida Administrative Code, National Certified Testing Laboratories hereby certifies the following:

- National Certified Testing Laboratories does not have, nor does it intend to acquire or will it acquire, a financial interest in any company manufacturing or distributing products tested or labeled by the agency.
- National Certified Testing Laboratories is not owned, operated or controlled by any company manufacturing or distributing products it tests or labels.
- Joseph A. Reed, P.E. does not have nor will acquire, a financial interest in any company manufacturing or distributing products for which the reports are being issued.
- Joseph A. Reed, P.E. does not have, nor will acquire, a financial interest in any other entity involved in the approval process of the product.



Analyses

Summary of Test Results

The following table summarizes the various Premium Vinyl Horizontal Sliding window products and their corresponding performance levels which have been established by testing or product certification.

Table 1 Summary of Test Results

Series/Model	Test Report Number	Size (W x H)	Performance
Premium Vinyl Horizontal Sliding Window (XO) (Through Frame and Fin Install)	SJW2015-051 (Rev -, 04/08/15)	72" x 60"	+50/-55 psf
Premium Vinyl Horizontal Sliding Window (XOX) (Fin Install)	SJW2014-132 (Rev -, 04/09/15)	96" x 60"	+50/-55 psf
Premium Vinyl Horizontal Sliding Window (XOX) (Through Frame Install)	SJW2014-133 (Rev -, 03/04/15)	96" x 60"	+50/-55 psf

Testing documented in Table 1 was conducted by the National Certified Testing Laboratories laboratory in Everett, Washington (Florida Department of Business & Professional Regulation Test Lab No. TST9341, A2LA Certificate 3054.03).

As-Tested Installation Analysis

For air/water/structural testing the test specimen was secured to a 2x Spruce-Pine-Fir buck. The as-tested installation methods are evaluated on page 4 to page 7. These capacities will be used to prove acceptable alternate anchors and substrates for the windows.

Alternate Anchorages

Calculations on page 8 through page 10 determine the design capacity of alternate installation anchorages for the window.

Anchorage Requirements

As-tested spacing must be maintained. It must be determined the anchorages are not overloaded for the approved window size and design pressures. Calculations presented on page 11 show the anchor spacing requirements for the established limiting anchor capacities.

Anchorage requirements established by this report are accurately presented in Drawing D014928 and D014563.



Attachments

Appendix A – Revision Log (1 page)



As-Tested Installation – Nail Fin to Wood

#8 x 1-1/4" Pan Head Screw

0.062" thick Nail Fin

Spruce-Pine-Fir 2x Wood Substrate Minimum (G=0.42)

Allowable Tension of #8 x 1-1/4" Pan Head Screw

$$W = 1.6(1.250"-0.062")(82 \text{ lb/in}) \quad (\text{NDS, Table 12.2B})$$
$$W = 156 \text{ lb}$$

Allowable Pull-Over of #8 x 1-1/4" Pan Head Screw

Validated by Testing

Window	Design Pressure (psf)	Width (inch)	Height (inch)	Head	Anchors at			Max Load to Anchor (lb)
					Sill	Jambs		
72 x 60	55	72	60	9	9	8	49	
96 x 60	55	96	60	12	12	8	55	

Test results prove anchor is OK for 55 lb.

Must maintain anchor spacing and anchor head size

Capacity of Connection is 55 lb



As-Tested Installation – Through Frame to Wood

#8 Pan Head Screw; 1-1/2" penetration to wood

0.060" thick Window Frame

1/4" Maximum Shim Space

Spruce-Pine-Fir 2x Wood Substrate Minimum (G=0.42)

Allowable Shear of #8 Pan Head Screw

Z' = 98 lb (See Following 2 Pages)

Bending of #8 Pan Head Screw

L = 1/4" (maximum shim space)

$S = \pi d^3/32 = \pi(0.131)^3/32 = 0.000221 \text{ in}^3$

$F_b = (1.3)(0.6F_y) = (1.3)(0.6)(90,000 \text{ psi}) = 70,200 \text{ psi}$ (1.3 weak axis factor)

$F_b = M/S = (VL/2)/S$ (L/2 for guided bending)

$V = 2SF_b/L = (2)(0.000221 \text{ in})(70,200 \text{ psi})/0.25" = 124 \text{ lb.}$

Capacity of Connection is 98 lb



As-Tested Installation – Through Frame to Wood (Continued)

Lateral Design Strength of Wood Connections

Data

Fastener

Fastener	=	#8 Wood Screw
Shank Dia	=	0.164 in.
Root Dia.	=	0.131 in.
F_{yb}	=	90,000 psi
Fastener length	=	2.000 in.

Main Member

Material	=	SPF
G	=	0.42
θ	=	90 \leq (Angle of load to grain $0^\circ \leq \theta \leq 90^\circ$)
F_e	=	3,350 psi
Thickness	=	1.500 in.

Side Member

Material	=	Vinyl (PVC)
G	=	N/A
θ	=	90 \leq (Angle of load to grain $0^\circ \leq \theta \leq 90^\circ$)
F_{es}	=	17,125 psi
Thickness	=	0.060 in.

Calculations

Lateral Bearing Factors

D	=	0.131 in.
ℓ_m	=	1.500 in.
K_θ	=	1.25
K_D	=	2.20
R_e	=	0.196
R_t	=	25.00
k_1	=	1.9318
k_2	=	0.6066
k_3	=	13.13



As-Tested Installation – Through Frame to Wood (Continued)

Yield Mode	R _d
I _m , I _s	2.20
II	2.20
III _m , III _s , IV	2.20

Lateral Design Values, Z

Mode I _m	=	299	lbf
Mode I _s	=	61	lbf
Mode II	=	118	lbf
Mode III _m	=	130	lbf
Mode III _s	=	72	lbf
Mode IV	=	101	lbf
C _D	=	1.6	

<===== Minimum Value

Wet Service Factor

Fabrication/In-Service	Dry/Dry
C _M	= 1.0
In service temperature	T ≤ 100°F
C _t	= 1.0
C _g	= 1.0
C _Δ	= 1.0
Is fastener installed in end grain?	No
C _{eg}	= 1.00
Is fastener part of a diaphragm?	No
C _{di}	= 1.0
Is fastener toe-nailed?	No
C _{tn}	= 1.00
Z'	= 98 lbf



Alternate Installation – Trough Frame to Steel Stud

#8 Grade 5 Screw

1/4" Maximum Shim Space

Minimum 18 gauge 33 KSI Steel Stud

Allowable Shear of #8 Grade 5 Screw

$$P_{ss}/\Omega = 286 \text{ lb (AAMA TIR A9)}$$

Bearing of #8 Grade 5 Screw on Frame

$$F_p = 10,000 \text{ psi}$$

$$D = 0.164''$$

$$t = 0.060''$$

$$V_a = F_p D t = (10,000 \text{ psi})(0.164'')(0.060'') = 98 \text{ lb}$$

Bearing of #8 Grade 5 Screw on Steel Stud

$$V_a = 2.7 D t F_{tu} / 3.0$$

$$V_a = 2.7(0.164'')(0.0428'')(45,000 \text{ psi}) / 3.0$$

$$V_a = 284 \text{ lb.}$$

Tilting of #8 Grade 5 Screw in Steel Stud

$$V_a = 4.2(t_2^3 D)^{1/2} F_{tu2} / n_s$$

$$V_a = 4.2(0.0428''^3 \times 0.164'')^{1/2} (45,000 \text{ psi}) / 3.0$$

$$V_a = 226 \text{ lb.}$$

Bending of #8 Grade 5 Screw

$$L = 1/4'' \text{ (Maximum Shim Space)}$$

$$S = \pi d^3 / 32 = \pi(0.116)^3 / 32 = 0.000153 \text{ in}^3$$

$$F_b = (1.3)(0.6 F_y) = (1.3)(0.6)(100,000 \text{ psi}) = 78,000 \text{ psi (1.3 weak axis factor)}$$

$$F_b = M/S = (V L / 2) / S \text{ (L/2 for guided bending)}$$

$$V = 2 S F_b / L = (2)(0.000153 \text{ in}^3)(78,000 \text{ psi}) / 0.25'' = 96 \text{ lb.}$$

Capacity of Connection is 96 lb.



Alternate Installation – Through Frame to Concrete

3/16" Tapcon Anchor

2" Minimum Edge Distance, 1-1/4" Minimum Embedment

1/4" Maximum Shim Space

Minimum $f'_c = 3,000$ psi Concrete

Allowable Shear of 3/16" Tapcon Anchor

$$P_{ss}/\Omega = 181 \text{ lb} \quad (\text{NOA-No. 16-1222.06})$$

Bearing of 3/16" Tapcon Anchor on Frame

$$F_p = 10,000 \text{ psi}$$

$$D = 0.170"$$

$$t = 0.060"$$

$$V_a = F_p D t = (10,000 \text{ psi})(0.170")(0.060") = 102 \text{ lb}$$

Bending of 3/16" Tapcon Anchor

$$L = 1/4" \text{ (Maximum Shim Space)}$$

$$S = \pi d^3/32 = \pi(0.170")^3/32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi (1.3 weak axis factor)}$$

$$F_b = M/S = (VL/2)/S \text{ (L/2 for guided bending)}$$

$$V = 2SF_b/L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi})/0.25" = 412 \text{ lb.}$$

Capacity of Connection is 102 lb



Alternate Installation – Through Frame to CMU

3/16" Tapcon Anchor

2" Minimum Edge Distance, 1-1/4" Minimum Embedment

1/4" Maximum Shim Space

Minimum ASTM C90 Concrete Masonry Unit

Allowable Shear of 3/16" Tapcon Anchor

$$P_{ss}/\Omega = 135 \text{ lb} \quad (\text{NOA-No. 16-1222.06})$$

Bearing of 3/16" Tapcon Anchor on Frame

$$F_p = 10,000 \text{ psi}$$

$$D = 0.170"$$

$$t = 0.060"$$

$$V_a = F_p D t = (10,000 \text{ psi})(0.170")(0.060") = 102 \text{ lb}$$

Bending of 3/16" Tapcon Anchor

$$L = 1/4" \text{ (Maximum Shim Space)}$$

$$S = \pi d^3/32 = \pi(0.170")^3/32 = 0.000482 \text{ in}^3$$

$$F_b = (1.3)(0.6F_y) = (1.3)(0.6)(137,000 \text{ psi}) = 106,860 \text{ psi} \text{ (1.3 for weak axis bending)}$$

$$F_b = M/S = (VL/2)/S \text{ (L/2 for guided bending)}$$

$$V = 2SF_b/L = (2)(0.000482 \text{ in}^3)(106,860 \text{ psi})/0.25" = 412 \text{ lb.}$$

Capacity of Connection is 102 lb



72x60 +50/-55 psf

Anchorage Requirements – Nail Fin

Window Overall Size: 72" x 60"
Window Overall Area: $(72")(60")/144 = 30.0 \text{ ft}^2$
Window Overall Wind Load: $(55 \text{ psf})(30.0 \text{ ft}^2) = 1,650 \text{ lb}$
Installed Anchors: 9 head + 9 sill + 2(8) jambs = 34 installed anchors
Minimum Anchor Capacity: 55 lb/anchor
Total Anchor Capacity: $(34 \text{ anchors})(55 \text{ lb/anchor}) = 1,870 \text{ lb} > 1,650 \text{ lb}$ **OK**

Anchorage Requirements – Through Frame

Window Overall Size: 72" x 60"
Window Overall Area: $(72")(60")/144 = 30.0 \text{ ft}^2$
Window Overall Wind Load: $(55 \text{ psf})(30.0 \text{ ft}^2) = 1,650 \text{ lb}$
Installed Anchors: 7 head + 7 sill + 2(6) jambs = 26 installed anchors
Minimum Anchor Capacity: 96 lb/anchor
Total Anchor Capacity: $(26 \text{ anchors})(96 \text{ lb/anchor}) = 2,496 \text{ lb} > 1,650 \text{ lb}$ **OK**

96x60 +50/-55 psf

Anchorage Requirements – Nail Fin

Window Overall Size: 96" x 60"
Window Overall Area: $(96")(60")/144 = 40.0 \text{ ft}^2$
Window Overall Wind Load: $(55 \text{ psf})(40.0 \text{ ft}^2) = 2,200 \text{ lb}$
Installed Anchors: 12 head + 12 sill + 2(8) jambs = 40 installed anchors
Minimum Anchor Capacity: 55 lb/anchor
Total Anchor Capacity: $(40 \text{ anchors})(55 \text{ lb/anchor}) = 2,200 \text{ lb} = 2,200 \text{ lb}$ **OK**

Anchorage Requirements – Through Frame

Window Overall Size: 96" x 60"
Window Overall Area: $(96")(60")/144 = 40.0 \text{ ft}^2$
Window Overall Wind Load: $(55 \text{ psf})(40.0 \text{ ft}^2) = 2,200 \text{ lb}$
Installed Anchors: 12 head + 12 sill + 2(6) jambs = 36 installed anchors
Minimum Anchor Capacity: 96 lb/anchor
Total Anchor Capacity: $(36 \text{ anchors})(96 \text{ lb/anchor}) = 3,456 \text{ lb} > 2,200 \text{ lb}$ **OK**



Appendix A

Revision Log

<u>Identification</u>	<u>Date</u>	<u>Page & Revision</u>
Original Issue	02/04/21	Not Applicable