



398 E DANIA BEACH BLVD. SUITE 338, DANIA BEACH, FL 33004

## Product Evaluation Report

*of*

**Euro-Wall, LLC  
Euro-Pivot Inswing and Outswing Door  
(Non-HVHZ) (Non-Impact)**

*for*

## Florida Product Approval

**FL# FL22410**

**Report No. 8479**

### Current Florida Building Code

<b>Method:</b>	<b>1 – D (Engineering Evaluation)</b>
<b>Category:</b>	<b>Exterior Doors</b>
<b>Sub – Category:</b>	<b>Swinging Exterior Door Assemblies</b>
<b>Product:</b>	<b>Euro-Pivot Inswing and Outswing Door</b>
<b>Materials:</b>	<b>Aluminum 6063-T5</b>
<b>Product Dimensions:</b>	<b>See Installation Instructions, EWS031</b>

### Prepared for:


**Euro-Wall, LLC  
24100 Tiseo Blvd.  
Port Charlotte, FL 33980**

### Prepared by:

**Hermes F. Norero, P.E.**  
Florida Professional Engineer # 73778  
Date: 06/07/2021

### Contents:

Evaluation Report      Pages 1 – 3



Hermes F. Norero, P.E.  
Florida No. 73778

**Manufacturer:** Euro-Wall, LLC

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Door Assemblies

**Compliance Method:** State Product Approval Method (1)(d)

**Product Name:** **Euro-Pivot Inswing and Outswing Door  
(Non-HVHZ) (Non-Impact)**

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) **Euro-Wall, LLC** based on Method 1d of the State of Florida Product Approval, Department of Business and Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the current Florida Building Code.

See Installation Instructions **EWS031**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

**Limits of Use:**

1. This product has been evaluated and is in compliance with the current Florida Building Code, **excluding** the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and **does require** an impact resistant covering in areas requiring impact resistance.
4. Site conditions that deviate from the details of installation instructions **EWS031** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **EWS031** for size and design pressure limitations.

