

Evaluation Report IN0370-R7
December 9, 2020

Product Description: Series 07-07 Center Hinge Outswing Impact Garden Door, OX or XO

Manufacturer: Simonton Windows, 1 Cochrane Ave., Pennsboro, WV

Statement of Compliance: This report evaluates the above-listed product per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). This product complies with the requirements of the 7th Edition (2020) Florida Building Code outside the High Velocity Hurricane Zone. The product testing standards performed are outlined below.

Technical Documentation:


- 1) This report, prepared by Lucas A. Turner, P.E., at 2428 Old Natchez Trc Trl, Camden, TN
- 2) Installation drawing IN0370-R7, signed and sealed by Lucas A. Turner, P.E.
- 3) Test Reports A2062 01-501-47-r0 and C3520.01-501-47-r1, from Architectural Testing, Inc., Springdale, PA, with testing performed: AAMA/WDMA/CSA 101/I.S.2/A440-05/08, ASTM E1886/1996-05
- 4) Supplemental Calculations to support IN0370-R7, signed and sealed by Lucas A. Turner, P.E.

Installation: Units must be installed according to installation drawing IN0370-R7.

Limitations of Use: This product:

- May be used in the configurations, product and DLO sizes, and with glazing as indicated in IN0370-R7
- Is large missile impact resistant (missile level D, wind zone 4) and does not require the use of shutters in windborne debris regions
- May not be used in the High Velocity Hurricane Zone
- Requires white Deceuninck PVC extrusions with current listing as an AAMA Certified Profile Licensee under AAMA 303

Certification of Independence: I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in Simonton Windows or in any company manufacturing or distributing products for which this report is being issued. I do not have, nor do I intend to acquire, nor will I acquire, a financial interest in any other entity involved in the testing or approval process of this product.



22

12/9/2020
Lucas A. Turner, P.E.
FL PE #58201