

# WOLTERS ENGINEERING

ENGINEERING, DRAFTING, CONSULTING

15211 97<sup>th</sup> Road N  
West Palm Beach, FL 33412  
Ph/Fx: (561) 225-1982

## PRODUCT EVALUATION

PRODUCT: 5V CRIMP 26 Ga. STEEL 24" WIDE ROOF PANEL  
OVER 7/16" OSB SHEATHING (FLPA# 24397.3)

MANUFACTURER: 1<sup>ST</sup> COAST METAL ROOFING SUPPLY  
186 STATE ROAD 207  
EAST PALATKA, FL 32131

To all concerned,

The 5V Crimp 26 Ga. Steel 24" Wide Roof Panel, manufactured by 1<sup>st</sup> Coast Metal Roofing Supply, is a non-structural galvalume coated steel roof panel (50 ksi min) that meets the requirements of Section 1507.4 of the 8<sup>th</sup> Edition (2023) Florida Building Code. The panel has been tested per UL 580 (2006) and UL 1897 (2004) by Force Engineering & Testing with results shown in test report 99-0284T-15A & B. I have reviewed UL 1897 (2004), and have determined that for this product it is equivalent to UL 1897 (2015), as referenced in the 8<sup>th</sup> Edition (2023) Florida Building Code.

### Technical Documentation:

1. Drawing "1CS5V1024" dated 10/11/23, signed and sealed by Scott Wolters, PE.
2. Test Reports listed above by Force Engineering & Testing, Inc. signed & sealed by Brandon Jasek, PE.
3. Supplemental Calculations to support 1CS5V1024, signed and sealed by Scott Wolters, PE.

I have reviewed this submittal per the requirements of FAC Product Approval Rule Chapter 61G20-3.005 (4). Based on the limitations listed below and those provided in the documents above, this product meets all of the requirements of the 8<sup>th</sup> Edition (2023) Florida Building Code generally, and chapter 15 specifically, for use outside of the High Velocity Hurricane Zone.

Limitations: This panel is approved for use outside of the HVHZ.

<u>Overall Limitations:</u>	Maximum Panel Width:	24" (nominal)
	Fastener Spacing across panel:	(2) fast's 12" O.C. (max) (both sides of Overlaps & Center Rib)
	Fastener Spacing along panel:	24" O.C. (max)
	Fastener Type:	#9 x 1 1/2" Woodbinder ST-XL HWH with Weather-seal washer
	Min. Slope:	1/2"/12" (with Lap Sealant) 3"/12" (no Lap Sealant)
	Max. Design Pressure:	-63.5 psf

Fire Barrier: Where required by code, install an approved fire barrier. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. (See note #2 below)

Underlayment: Minimum ASTM D 226 Type II, installed and anchored per FBC Section 1507.1.1.1 (min).  
(or)

Any underlayment with a valid FLPA or Miami-Dade NOA

Minimum Substrate: 7/16" OSB Sheathing, nailed to 2x rafters spaced 24" O.C. (max) with 8d ring-shank nails spaced 6" O.C. (max).


Other Limitations:

1. Roof slope must meet requirements of FBC Section 1507.4.2.
2. Fire classification is not a part of this evaluation. Refer to a current Approved Roofing Materials Directory for fire ratings of this product.
3. Design of substrate is by others and is not a part of this evaluation.
4. All panel system perimeters, penetrations, and transitions to be flashed and sealed per the requirements of RAS 133.

Re-Roofing: The 5V Crimp 26 Ga. Steel 24" Wide Roof Panel may be installed over a single layer of existing asphalt shingles, provided the existing roof meets all of the requirements of Section 1511 of the Florida Building Code.

If you have any questions or need more information concerning this approval, please contact me.

Thank you,

  
Scott Wolters  
FL PE# 62354  
OCT 11 2023

