

L. Roberto Lomas P.E.

400 S Palm Ave
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514279B

Manufacturer: US Aluminum
950 Solon Rd.
Waxahachie, TX 75165

Product Line: D900 Out-Swing Hinged Door – Accessible Threshold w/Standard or 10" bottom rail, Large Missile Impact

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03296 Revision B, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: H6776.01-303-18 R1 signed and sealed by Tyler Westerling P.E.
Intertek, Lake Forest, CA.
TAS 201/TAS 203 Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Pressure loading ± 80.0 psf design pressure
TAS 202 Uniform Static Air Pressure, ± 80.0 psf design pressure, 15.04psf water penetration.
3. Test report No.: I7466.01-303-18 R1 (accessible threshold) signed and sealed by Tyler Westerling P.E.
Intertek, Lake Forest, CA.
TAS 201/TAS 203 Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Pressure loading ± 80.0 psf design pressure
TAS 202 Uniform Static Air Pressure, ± 80.0 psf design pressure, 15.04psf water penetration.
4. Test report No.: I9228.01-303-18 R1 (accessible threshold with 10" bottom rail) signed and sealed by Tyler Westerling P.E.
Intertek, Lake Forest, CA.
TAS 201/TAS 203 Large Missile Impact Test, Level D, Wind Zone 4
Cyclic Pressure loading ± 80.0 psf design pressure
TAS 202 Uniform Static Air Pressure, ± 80.0 psf design pressure, 15.04psf water penetration.
5. Anchor calculations, report number 514279-1B, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ± 80.0 psf
- Unit size: 42" x 96"
- Units must be glazed per ASTM E1300, according to glazing details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Extruded Aluminum 6063-T5.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03296, Revision A.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

