



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

398 E Dania Beach Blvd.  
Suite 338  
Dania Beach, FL 33004  
954.399.8478 PH  
954.744.4738 FX  
contact@buildingdrops.com

## Product Evaluation Report

*of*

**JELD-WEN, inc.**  
**Architectural Fiberglass Inswing Full Lite Door**  
**(Non-Impact) (HVHZ)**

*for*

**Florida Product Approval**

**Report No. 6277**

**Current Florida Building Code**

**Method:** 1 – A (Certificate Method)  
**Category:** Exterior Doors  
**Sub – Category:** Swinging Exterior Door Assemblies

**Product:** *Architectural Fiberglass Inswing Full Lite Door*  
**Material:** Wood/Fiberglass  
**Product Dimensions:** 37.5" x 81.25"

**Prepared for:**  
**JELD-WEN, inc.**  
**3737 Lakeport Blvd.**  
**Klamath Falls, OR 97601**

**Prepared by:**  
**Hermes F. Norero, P.E.**  
Florida Professional Engineer # 73778  
Date: 06/11/2019

Contents:  
Evaluation Report Pages 1 – 3



Hermes F. Norero, P.E.  
Florida No. 73778



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 06/11/2019

Report No: 6277

---

**Manufacturer:** JELD-WEN, inc.

**Product Category:** Exterior Doors

**Product Sub-Category:** Swinging Exterior Door Assemblies

**Compliance Method:** State Product Approval Method (1)(a)

**Product Name:** Architectural Fiberglass Inswing Full Lite Door

**Scope:** This is a Product Evaluation Report issued by Hermes F. Norero, P.E. (FL # 73778) for **JELD-WEN, inc.** based on Method 1a of the State of Florida Product Approval, Florida Department of Business & Professional Regulation - Florida Building Commission.

Hermes F. Norero, P.E. does not have nor will acquire financial interest in the company manufacturing or distributing the product or in any other entity involved in the approval process of the product named herein.

This product has been evaluated for use in locations adhering to the Current Florida Building Code.

See Installation Instructions **D015527**, signed and sealed by Hermes F. Norero, P.E. (FL # 73778) for specific use parameters.

## Limits of Use:

1. This product has been evaluated and is in compliance with the current Florida Building Code, including the "High Velocity Hurricane Zone" (HVHZ).
2. Product anchors shall be as listed and spaced as shown on details. Anchor embedment into substrate material shall be beyond wall dressing or stucco.
3. When used in areas requiring wind borne debris protection this product complies with Chapter 16 of the current Florida Building Code and does require an impact resistant covering.
4. Site conditions that deviate from the details of drawing **D015527** require further engineering analysis by a licensed engineer or registered architect.
5. See Installation Instructions **D015527** for size and design pressure limitations.



# BUILDING DROPS

A Perfect Solution in Every Drop!

Certificate of Authorization: 29578

Date: 06/11/2019

Report No: 6277

**Certification Agency:** The manufacturer has demonstrated compliance of products in accordance with the Florida Building Code for manufacturing under a program audited by and approved by **National Accreditation & Management Institute** (FBC Organization #: CER1773).

**Performance Standards:** The product described herein has been tested per:

- TAS 202-94

**Referenced Data:**

1. Product Testing performed by **National Certified Testing Laboratory** (FBC Organization # TST9341)  
Report: NCTL-310-19-041, Report Date: 03/28/2019
2. Certification Agency  
**National Accreditation & Management Institute**  
(FBC Organization #CER1773)

**Installation:**

Refer to Installation Instructions (**D015527**) for anchor spacing and more details of the installation requirements.

**Design Pressure:**

Configuration	Size	Design Pressure
X	37.5" x 81.25 "	+50/-55 PSF