

*L. Roberto Lomas P.E.*

1432 Woodford Rd.  
Lewisville, NC 27023  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

**Report No.: 514179**

**Manufacturer:** All Seasons Commercial  
1293 North Harvey Mitchell Parkway  
Bryan, TX 77803

**Product Line:** Series E4000FO Fixed Frame Offset Aluminum Fixed Window 48" x 120" Non-Impact

**Compliance:**

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03226, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: CCLI 14-111 signed by Wesley Wilson.  
Construction Consulting Laboratory, Carrollton, TX  
AAMA/WDMA/CSA 101/I.S.2/A440-08  
Design pressure:  $\pm 120.0$ psf  
Water penetration resistance 12.0psf
3. Anchor calculations, report number 514179-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure:  $\pm 120.0$ psf
- Unit size: 48" x 120"
- Units must be glazed per ASTM E1300-04/09.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and does require impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T5

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03226.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

