

L. Roberto Lomas P.E.

208 7th Ave
Indialantic, FL 32903
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514177B

Manufacturer: All Seasons Commercial
1293 North Harvey Mitchell Parkway
Bryan, TX 77803

Product Line: Series 3250 Aluminum Fixed Window 60" x 99" Non-Impact

Compliance:

The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03224 revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: CCLI 17-004 signed by Wesley Wilson.
Construction Consulting Laboratory, Carrollton, TX
AAMA/WDMA/CSA 101/I.S.2/A440
Design pressure: ±80.0psf
Water penetration resistance 12.0psf
3. Anchor calculations, report number 514177-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Design pressure: ±80.0psf
- Unit size: 60" x 99"
- Units must be glazed per ASTM E1300.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and does require impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T5

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03224, revision A.

Certification of Independence:

Please note that I do not have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I do not have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

