## L. Roberto Lomas P.E.

# **Engineering Evaluation Report**

1432 Woodford Rd. Lewisville, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Report No.: 514247

**Manufacturer:** All Seasons Commercial

1293 North Harvey Mitchell Parkway

Bryan, TX 77803

Product Line: Series 3250 Aluminum Single Hung Window 60" x 84" - Impact

#### Compliance:

The above mentioned product has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

## Supporting Technical Documentation:

- 1. Approval document: drawing number 08-03274, prepared, signed and sealed by Luis Roberto Lomas P.E.
- 2. Test report No.: CCLI 17-164 signed by Wesley Wilson.

Construction Consulting Laboratory, Carrollton, TX

AAMA/WDMA/CSA 101/l.S.2/A440-08
Design pressure: ±75.19psf
Water penetration resistance 12.11psf

 Test report No.: CCLI 18-057 signed by Wesley Wilson. Construction Consulting Laboratory, Carrollton, TX

AAMA 506

ASTM E1996-05 Large Missile Impact, Level D, Wind Zone 4
ASTM E1996-05 Cyclic Load Test, +75.0/-85.0psf design pressure

4. Anchor calculations, report number 514247-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

### Limitations and Conditions of use:

Maximum design pressure: ±75.0psf
Unit size: ±76.0psf
60" x 84"


- Units must be glazed per ASTM E1300-04/09, according to glazing details in approval drawing.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T5

## Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03274.

#### Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).



Luis R. Lomas, P.E. FL No.: 62514 08/06/2018