

L. Roberto Lomas P.E.

1432 Woodford Rd.
Lewisville, NC 27023
434-688-0609
rlomas@lrlomaspe.com

Engineering Evaluation Report

Report No.: 514630

Manufacturer: Eastern Architectural Systems
16341 Domestic Avenue
Ft. Myers, FL 33912

Product Line: Series 650 Vinyl Sliding Glass Door w/ and w/o pocket CW-PG45 Non-Impact

Compliance: The product mentioned above has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(a). The product listed herein complies with requirements of the current Florida Building Code.

Supporting Technical Documentation:

1. Approval document: drawing number 08-03549, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: NCTL-210-4143-02A signed by Christopher Bennet.
National Certified Testing Laboratories, Orlando, FL.
AAMA/WDMA/CSA 101/I.S.2/A440-11
Design pressure: ±45.0psf
Water penetration resistance: 6.75psf (with 0.522" sill riser)
9.0psf (with 1.44" sill riser)
12.0psf (with 1.94" sill riser)
3. Test report No.: NCTL-210-4143-03A signed by Christopher Bennet.
National Certified Testing Laboratories, Orlando, FL.
AAMA/WDMA/CSA 101/I.S.2/A440-11
Design pressure: ±45.0psf
Water penetration resistance: 6.75psf without sill riser
9.0psf (with 0.522" sill riser)
12.0psf (with 1.44" sill riser)
15.0psf (with 1.94" sill riser)
4. Anchor calculations, report number 514630-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

Limitations and Conditions of use:

- Maximum design pressure: ±45.0psf
- Panel size: 50 ¼" x 92 11/16"
- Units must be glazed per ASTM E1300-04/09 with safety glazing.
- This product is not rated to be used in the HVHZ.
- This product is not impact resistant and requires impact protection in wind borne debris regions.
- Frame material to be Vinyl PVC.
- Approved configurations: Multiple panels in 2track, 3track or 4track are approved as long as individual panel area does not exceed 32.38 ft².
- Units must be installed with 0.522" or 1.44" or 1.94" sill riser.

Installation:

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03549.

Certification of Independence:

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

