

*L. Roberto Lomas P.E.*

400 S Palm Ave  
Indialantic, FL 32903  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 514135A

**Manufacturer:** U.S. Aluminum  
950 Solon Rd.  
Waxahachie, TX 75165

**Product Line:** IW8200 Horizontal Sliding Window – Large Missile Impact

**Compliance:**

The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03201 Revision A, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: H0916.01-303-44 R3 signed and sealed by Tyler Westerling P.E.  
Intertek, Lake Forest, CA  
TAS 201 / TAS 203 Large Missile Impact Test, Level D, Wind Zone 4  
Cyclic Pressure loading  $\pm 100.0$ psf design pressure  
TAS 202 -94 Uniform Static Air Pressure,  $\pm 100.0$ psf design pressure, 12.11psf water penetration.
3. Anchor calculations, report number 514135-1A, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Design pressure:  $\pm 100.0$ psf
- Unit size: 71" x 60"
- Units must be glazed per ASTM E1300, according with glass details in approval drawing.
- This product is rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Extruded Aluminum 6063-T5.

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03201. Revision A.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

