

August 10, 2022

Fred Grunewald
Quaker Windows & Doors ("Customer")
P.O. Box 128
504 Highway 63 South
Freeburg, MO 65035

Dear Mr. Grunewald,

**M600 Awn ov Fix & Fix ov Awn
Waiver of Retest from N8359.01-122-34-r0**

Intertek conducted a review of test report #L5050.01-801-44 for Quaker ModernVu (M600) Aluminum Fixed and Awning (Project Out) Window, which was tested for AAMA/WDMA/CSA 101/L2.2/A440-08, AAMA 910-10, and ASTM F288.14. The configuration tested was Fixed/Awning (Project Out)/Fixed. Overall tested size was 60" wide x 144" tall to 70 psf.

After review of the tested configuration, the Awning/Fixed and Fixed/Awning configurations, shown on 7 pages of Installation instructions dated 8/8/2022, limited to the same size and design pressure for each Awning and Fixed are covered by the tested configuration. Frame members are equal to or exceed the structural capacity of the tested members. Anchor methods are equal to or exceed the capacity of the tested anchor method.

Yours sincerely,

Tanya Dolby, P.E.
Senior Engineer – Engineering Services
Building & Construction

