

*L. Roberto Lomas P.E.*

1432 Woodford Rd.  
Lewisville, NC 27023  
434-688-0609  
rlomas@lrlomaspe.com

## Engineering Evaluation Report

Report No.: 514383A

**Manufacturer:** All Seasons Commercial  
1293 North Harvey Mitchell Parkway  
Bryan, TX 77803

**Product Line:** 3250 Aluminum Horizontal Sliding Window – Impact

**Compliance:**

The product mentioned above has been evaluated for compliance with the requirements of the Florida Department of Business and Professional Regulation for Statewide Acceptance per Rule 61G20-3.005 method 1(d). The product listed herein complies with requirements of the current Florida Building Code.

**Supporting Technical Documentation:**

1. Approval document: drawing number 08-03385, prepared, signed and sealed by Luis Roberto Lomas P.E.
2. Test report No.: CCLI 18-059 signed by Wesley Wilson  
Construction Consulting Laboratory, Carrollton, TX.  
AAMA/WDMA/CSA 101/I.S.2/A440  
Design pressure: ±50.13psf  
Water penetration resistance 10.0psf  
ASTM E1886/ E1996 Large Missile Impact, Level D, Wind Zone 4  
Cyclic Load Test, +60.15/-75.19psf design pressure
3. Anchor calculations, report number 514383-1, prepared, signed and sealed by Luis Roberto Lomas P.E.

**Limitations and Conditions of use:**

- Maximum design pressure: ±50.0psf
- Unit size: 96" x 60"
- Units must be glazed per ASTM E1300, according to glazing details in approval drawing.
- This product is not rated to be used in the HVHZ.
- This product is impact resistant and does not require impact protection in wind borne debris regions.
- Frame material to be Aluminum 6063-T5

**Installation:**

Units must be installed in accordance with manufacturer's installation instructions and approval document 08-03385.

**Certification of Independence:**

Please note that I don't have nor will acquire a financial interest in any company manufacturing or distributing the product(s) for which this report is being issued. Also, I don't have nor will acquire a financial interest in any other entity involved in the approval process of the listed product(s).

