

# AL-FAROOQ CORPORATION

CONSULTING ENGINEERS & PRODUCT DEVELOPMENT

**PRODUCT APPROVAL EVALUATION  
RULE CHAPTER #61G20-3 • METHOD 1 OPTION D**

**FL 29846  
Date: 10/14/2020**

**Detailed Product Description:**


**Manufacturer:** QUICKMOUNT

**Manufacturer Address:** 28357 INDUSTRIAL BLVD. HAYWARD, CA 94545

**Model Name:** QUICKMOUNT QBASE MOUNT & L-MOUNT SOLAR ROOF ATTACHMENTS

**Impact Type:** NON-IMPACT

**Installation Drawings #** 20-79

This product does not comply with the High Velocity Hurricane Zone (HVHZ) testing requirements.					
For maximum wind uplift and shear resistance vs mounting type refer to installation drawings.					
<b>Tested in accordance with TAS-105</b>					
TEST	DESCRIPTION	TEST LOCATION	TEST REPORT DATE	TEST REPORT #	TEST SEALED BY
TAS 105	Field Withdrawal Resistance Testing (Lateral & Uplift)	Atlantic & Caribbean Roof Consulting, LLC	5/2/2019 6/27/19	ACRC 19-0207	Randall Fowler, PE
Under the limitations of the attached installation drawings, to the best of my knowledge and ability, the above product conforms to the requirements of the 2020 Florida Building Code.					
<b>Evaluation Report Engineer:</b>			 Sealed: 10/21/2020		
Jalal Farooq Al-Farooq Corporation		PE # 81223 EB # 3538			